

表3：2017年5月山西省污水处理厂监督性监测结果

行政区(市)	行政区(县区)	污水处理厂名称	监测日期	执行标准名称	监测项目	进口浓度(mg/L)	出口浓度(mg/L)	标准限值(mg/L)	排放单位	是否达标	超标倍数
大同市	城 区	大同市东郊污水处理厂	2017/5/2	城镇污水处理厂污染物排放标准	温度	20	18.2				
					PH值		7.85	6-9	无量纲	是	
					生化需氧量		6	10	mg/L	是	
					总磷		0.38	1	mg/L	是	
					化学需氧量	185	29	50	mg/L	是	
					色度		10	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.0001	0.01	mg/L	是	
					总铬		<0.005	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.001	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂(LAS)		0.186	0.5	mg/L	是	
					粪大肠菌群数		950	1000	mg/L	是	
					氨氮	61.2	4.64	5	mg/L	是	
					总氮		9.72	15	mg/L	是	
					石油类		0.12	1	mg/L	是	
					动植物油		0.16	1	mg/L	是	
大同市	城 区	大同市西郊污水处理厂	2017/5/2	城镇污水处理厂污染物排放标准	温度	18.2	19				
					PH值		8.02	6-9	无量纲	是	
					生化需氧量		7	10	mg/L	是	
					总磷		0.48	1	mg/L	是	
					化学需氧量	216	41	50	mg/L	是	
					色度		5	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.0001	0.01	mg/L	是	
					总铬		<0.005	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.001	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂(LAS)		0.225	0.5	mg/L	是	
					粪大肠菌群数		820	1000	mg/L	是	
					氨氮	77	1.33	5	mg/L	是	
					总氮		6.4	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
					动植物油		0.11	1	mg/L	是	

大同市	南郊区	大同煤矿集团有限责任公司生活污水处理分公司	2017/5/9	城镇污水处理厂污染物排放标准	温度	16	16				
					PH值		7.76	6-9	无量纲	是	
					生化需氧量		7	10	mg/L	是	
					总磷		0.76	0.5	mg/L	否	0.5
					化学需氧量	112	42	50	mg/L	是	
					色度		10	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.0001	0.01	mg/L	是	
					总铬		<0.005	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0008	0.1	mg/L	是	
					总铅		<0.001	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.16	0.5	mg/L	是	
					粪大肠菌群数		450	1000	个/L	是	
					氨氮	75.7	1.62	5	mg/L	是	
					总氮		16.8	15	mg/L	否	0.1
					石油类		0.07	1	mg/L	是	
					动植物油		0.08	1	mg/L	是	
大同市	天镇县	天镇县源洁污水处理有限公司	2017/5/4	城镇污水处理厂污染物排放标准	温度	19	18.6				
					PH值		7.78	6-9	无量纲	是	
					生化需氧量		6	20	mg/L	是	
					总磷		0.47	1	mg/L	是	
					化学需氧量	192	31	60	mg/L	是	
					色度		5	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.0001	0.01	mg/L	是	
					总铬		<0.005	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.001	0.1	mg/L	是	
					悬浮物		8	20	mg/L	是	
					阴离子表面活性剂 (LAS)		0.096	1	mg/L	是	
					粪大肠菌群数		200	10000	个/L	是	
					氨氮	37.4	4.64	8	mg/L	是	
					总氮		8.56	20	mg/L	是	
					石油类		<0.04	3	mg/L	是	
					动植物油		0.05	3	mg/L	是	

阳泉市	矿 区	阳泉煤业集团有限责任公司升华实业分公司	2017/5/9	城镇污水处理厂污染物排放标准	PH值	7.72	7.98	6-9	无量纲	是	
					生化需氧量	147	2.2	10	mg/L	是	
					总磷		1.84	0.5	mg/L	否	2.7
					化学需氧量	363	36	50	mg/L	是	
					色度		2	30	倍	是	
					总汞	0.0001	<0.00004	0.001	mg/L	是	
					总镉	<0.001	<0.001	0.01	mg/L	是	
					总铬	<0.004	<0.004	0.1	mg/L	是	
					六价铬	<0.004	<0.004	0.05	mg/L	是	
					总砷	0.0086	0.0031	0.1	mg/L	是	
					总铅	<0.01	<0.01	0.1	mg/L	是	
					悬浮物	185	16	10	mg/L	否	0.6
					阴离子表面活性剂 (LAS)		0.1	0.5	mg/L	是	
					粪大肠菌群数		73000	1000	个/L	否	72
					氨氮	26.4	0.192	5	mg/L	是	
					总氮		25.1	15	mg/L	否	0.7
					石油类		<0.04	1	mg/L	是	
					动植物油		<0.04	1	mg/L	是	
					温度	22.4	22.2				
					阳泉市	郊 区	深港水务有限公司污水处理厂	2017/5/18	城镇污水处理厂污染物排放标准	PH值	7.91
生化需氧量	30.9	1.1	10	mg/L						是	
总磷		0.39	0.5	mg/L						是	
化学需氧量	275	31	50	mg/L						是	
色度		1	30	倍						是	
总汞	0.00016	<0.00004	0.001	mg/L						是	
总镉	<0.001	<0.001	0.01	mg/L						是	
总铬	<0.004	<0.004	0.1	mg/L						是	
六价铬	<0.004	<0.004	0.05	mg/L						是	
总砷	0.0013	<0.0003	0.1	mg/L						是	
总铅	<0.01	<0.01	0.1	mg/L						是	
悬浮物	200	15	10	mg/L						否	0.5
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是	
粪大肠菌群数		350	1000	个/L						是	
氨氮	22.2	0.061	5	mg/L						是	
总氮		9.22	15	mg/L						是	
石油类		<0.04	1	mg/L						是	
动植物油		<0.04	1	mg/L						是	
温度	18.8	18.8									

阳泉市	平定县	平定中玮水质净化有限公司	2017/5/11	城镇污水处理厂污染物排放标准	PH值	7.85	7.91	6-9	无量纲	是						
					生化需氧量	89.4	1.4	10	mg/L	是						
					总磷		0.06	0.5	mg/L	是						
					化学需氧量	352	38	50	mg/L	是						
					色度		1	30	倍	是						
					总汞	0.00025	<0.00004	0.001	mg/L	是						
					总镉	<0.001	<0.001	0.01	mg/L	是						
					总铬	<0.004	<0.004	0.1	mg/L	是						
					六价铬	<0.004	<0.004	0.05	mg/L	是						
					总砷	0.004	0.0009	0.1	mg/L	是						
					总铅	<0.01	<0.01	0.1	mg/L	是						
					悬浮物	576	7	10	mg/L	是						
					阴离子表面活性剂 (LAS)		0.14	0.5	mg/L	是						
					粪大肠菌群数		350	1000	个/L	是						
					氨氮	46.1	0.436	5	mg/L	是						
					总氮		5.99	15	mg/L	是						
					石油类		<0.04	1	mg/L	是						
					动植物油		<0.04	1	mg/L	是						
					阳泉市	平定县	阳泉昇阳污水净化有限公司	2017/5/18	城镇污水处理厂污染物排放标准	温度	21.5	21.5				
										总磷		0.35	0.5	mg/L	是	
总氮		12.5	15	mg/L						是						
石油类		<0.04	1	mg/L						是						
动植物油		<0.04	1	mg/L						是						
色度		1	30	倍						是						
总汞	0.00019	<0.00004	0.001	mg/L						是						
总镉	<0.001	<0.001	0.01	mg/L						是						
总铬	<0.004	<0.004	0.1	mg/L						是						
六价铬	<0.004	<0.004	0.05	mg/L						是						
总砷	0.0016	<0.0003	0.1	mg/L						是						
总铅	<0.01	<0.01	0.1	mg/L						是						
悬浮物	587	11	10	mg/L						否	0.1					
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是						
粪大肠菌群数		4800	1000	个/L						否	3.8					
地表水环境质量标准	PH值	7.85	7.72	6-9						无量纲	是					
	生化需氧量	28.9	1.1	10						mg/L	是					
	氨氮	39.9	0.524	2					mg/L	是						
	化学需氧量	329	28	40					mg/L	是						

阳泉市	孟 县	山西孟县正阳污水净化有限公司	2017/5/15	城镇污水处理厂污染物排放标准	PH值	7.82	8.16	6-9	无量纲	是						
					生化需氧量	71.6	1	10	mg/L	是						
					总磷		0.32	0.5	mg/L	是						
					化学需氧量	397	16	50	mg/L	是						
					色度		8	30	倍	是						
					总汞	0.00017	0.00005	0.001	mg/L	是						
					总镉	<0.001	<0.001	0.01	mg/L	是						
					总铬	<0.004	<0.004	0.1	mg/L	是						
					六价铬	<0.004	<0.004	0.05	mg/L	是						
					总砷	0.0015	0.0007	0.1	mg/L	是						
					总铅	<0.01	<0.01	0.1	mg/L	是						
					悬浮物	1040	13	10	mg/L	否	0.3					
					阴离子表面活性剂 (LAS)		0.28	0.5	mg/L	是						
					粪大肠菌群数		<3	1000	个/L	是						
					氨氮	30.3	0.204	5	mg/L	是						
					总氮		13.3	15	mg/L	是						
					石油类		<0.04	1	mg/L	是						
					动植物油		<0.04	1	mg/L	是						
					朔州市	朔州市	华电水务朔州有限公司	2017/5/18	城镇污水处理厂污染物排放标准	温度	18.2	18.2				
										温度	17.5	20.6				
PH值		7.28	6-9	无量纲						是						
生化需氧量		2.9	10	mg/L						是						
总磷		0.296	0.5	mg/L						是						
化学需氧量	298	26	50	mg/L						是						
色度		24	30	倍						是						
总汞		<0.00004	0.001	mg/L						是						
总镉		<0.01	0.01	mg/L						是						
总铬		0.008	0.1	mg/L						是						
六价铬		0.004	0.05	mg/L						是						
总砷		<0.0003	0.1	mg/L						是						
总铅		<0.08	0.1	mg/L						是						
悬浮物		8	10	mg/L						是						
阴离子表面活性剂 (LAS)		0.07	0.5	mg/L						是						
粪大肠菌群数		138	1000	个/L						是						
氨氮	44	0.116	5	mg/L						是						
总氮		5.16	15	mg/L						是						
石油类		0.09	1	mg/L						是						
动植物油		0.014	1	mg/L						是						

晋中市	榆次区	山西正阳污水净化有限公司(二厂)	2017/5/11	城镇污水处理厂污染物排放标准	温度	21	19.5				
					PH值		7.98	6-9	无量纲	是	
					生化需氧量		2.4	10	mg/L	是	
					总磷		0.394	0.5	mg/L	是	
					化学需氧量	352	17	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00018	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0027	0.1	mg/L	是	
					总铅		0.00024	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂(LAS)		0.09	0.5	mg/L	是	
					粪大肠菌群数		41	1000	个/L	是	
					氨氮	46.7	2.75	5	mg/L	是	
					总氮		10.3	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
					动植物油		0.03	1	mg/L	是	
晋中市	榆次区	山西正阳污水净化有限公司(一厂)	2017/5/12	城镇污水处理厂污染物排放标准	温度	19.9	19.2				
					PH值		7.7	6-9	无量纲	是	
					生化需氧量		1.7	10	mg/L	是	
					总磷		0.948	1	mg/L	是	
					化学需氧量	357	14	50	mg/L	是	
					色度		2	30	倍	是	
					总汞		0.00013	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0009	0.1	mg/L	是	
					总铅		0.00038	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂(LAS)		0.09	0.5	mg/L	是	
					粪大肠菌群数		<3	1000	mg/L	是	
					氨氮	63.9	0.312	5	mg/L	是	
					总氮		9.11	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
					动植物油		<0.01	1	mg/L	是	

晋中市	榆社县	榆社县污水处理中心	2017/5/10	城镇污水处理厂污染物排放标准	温度	17.2	16.7				
					PH值		7.87	6-9	无量纲	是	
					生化需氧量		2.8	10	mg/L	是	
					总磷		0.433	0.5	mg/L	是	
					化学需氧量	167	18	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.001	0.1	mg/L	是	
					总铅		0.00036	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.11	0.5	mg/L	是	
					粪大肠菌群数		160	1000	个/L	是	
					氨氮	29	0.341	5	mg/L	是	
					总氮		13.8	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
					动植物油		0.03	1	mg/L	是	
晋中市	左权县	左权县污水处理中心	2017/5/9	城镇污水处理厂污染物排放标准	温度	14.1	15.4				
					PH值		7.45	6-9	无量纲	是	
					生化需氧量		6	10	mg/L	是	
					总磷		0.365	0.5	mg/L	是	
					化学需氧量	294	35	50	mg/L	是	
					色度		13	30	倍	是	
					总汞		0.00019	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0022	0.1	mg/L	是	
					总铅		0.00061	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.11	0.5	mg/L	是	
					粪大肠菌群数		18	1000	个/L	是	
					氨氮	54.1	2.07	5	mg/L	是	
					总氮		6.98	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
					动植物油		0.04	1	mg/L	是	

晋中市	和顺县	和顺景盛污水处理有限责任公司	2017/5/9	城镇污水处理厂污染物排放标准	温度	15.5	12.8				
					PH值		7.51	6-9	无量纲	是	
					生化需氧量		3.4	10	mg/L	是	
					总磷		0.311	0.5	mg/L	是	
					化学需氧量	275	22	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00014	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0005	0.1	mg/L	是	
					总铅		0.00042	0.1	mg/L	是	
					悬浮物		9	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.08	0.5	mg/L	是	
					粪大肠菌群数		390	1000	个/L	是	
					氨氮	21.6	0.269	5	mg/L	是	
					总氮		9.61	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
					动植物油		0.04	1	mg/L	是	
晋中市	昔阳县	昔阳县污水处理中心	2017/5/10	城镇污水处理厂污染物排放标准	温度	15.6	16.1				
					PH值		7.32	6-9	无量纲	是	
					生化需氧量		3.6	10	mg/L	是	
					总磷		0.453	0.5	mg/L	是	
					化学需氧量	217	22	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0007	0.1	mg/L	是	
					总铅		0.00026	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.09	0.5	mg/L	是	
					粪大肠菌群数		120	1000	个/L	是	
					氨氮	35.7	0.347	5	mg/L	是	
					总氮		13.2	15	mg/L	是	
					石油类		0.01	1	mg/L	是	
					动植物油		0.03	1	mg/L	是	

晋中市	祁 县	祁县鸿宇市政污水处理有限公司	2017/5/15	城镇污水处理厂污染物排放标准	温度	22.3	20				
					PH值		7.42	6-9	无量纲	是	
					生化需氧量		5.2	10	mg/L	是	
					总磷		0.451	0.5	mg/L	是	
					化学需氧量	422	31	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0017	0.1	mg/L	是	
					总铅		0.00043	0.1	mg/L	是	
					悬浮物		10	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.14	0.5	mg/L	是	
					粪大肠菌群数		8	1000	个/L	是	
					氨氮	62.4	0.59	5	mg/L	是	
					总氮		9.51	15	mg/L	是	
					石油类		0.01	1	mg/L	是	
动植物油		0.06	1	mg/L	是						
晋中市	平遥县	平遥县瑞思污水处理有限公司	2017/5/16	城镇污水处理厂污染物排放标准	温度	21.8	22.4				
					PH值		7.96	6-9	无量纲	是	
					生化需氧量		2.4	10	mg/L	是	
					总磷		0.468	0.5	mg/L	是	
					化学需氧量	402	16	50	mg/L	是	
					色度		2	30	倍	是	
					总汞		0.00012	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0005	0.1	mg/L	是	
					总铅		0.00096	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.14	0.5	mg/L	是	
					粪大肠菌群数		230	1000	个/L	是	
					氨氮	99.7	2.88	5	mg/L	是	
					总氮		13.5	15	mg/L	是	
					石油类		0.02	1	mg/L	是	
动植物油		0.06	1	mg/L	是						

晋中市	灵石县	灵石县保净污水处理有限公司	2017/5/16	城镇污水处理厂污染物排放标准	温度	18.5	21				
					PH值		8.38	6-9	无量纲	是	
					生化需氧量		0.8	10	mg/L	是	
					总磷		0.454	0.5	mg/L	是	
					化学需氧量	881	17	50	mg/L	是	
					色度		2	30	倍	是	
					总汞		0.00021	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0005	0.1	mg/L	是	
					总铅		0.00083	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.02	0.5	mg/L	是	
					粪大肠菌群数		<3	1000	个/L	是	
					氨氮	81.7	0.405	5	mg/L	是	
					总氮		10	15	mg/L	是	
					石油类		<0.01	1	mg/L	是	
动植物油		0.02	1	mg/L	是						
晋中市	介休市	介休市帅达污水处理有限公司	2017/5/17	城镇污水处理厂污染物排放标准	温度	19.9	20.8				
					PH值		7.42	6-9	无量纲	是	
					生化需氧量		3.3	10	mg/L	是	
					总磷		0.131	0.5	mg/L	是	
					化学需氧量	353	21	50	mg/L	是	
					色度		16	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.00005	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0008	0.1	mg/L	是	
					总铅		0.00053	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.19	0.5	mg/L	是	
					粪大肠菌群数		250	1000	个/L	是	
					氨氮	56	0.873	5	mg/L	是	
					总氮		2.65	15	mg/L	是	
					石油类		0.05	1	mg/L	是	
动植物油		0.12	1	mg/L	是						

运城市	夏 县	夏县污水处理中心	2017/5/19	城镇污水处理厂污染物排放标准	温度	23.3	21.5				
					PH值		7.74	6-9	无量纲	是	
					生化需氧量		5.5	10	mg/L	是	
					总磷		0.48	0.5	mg/L	是	
					化学需氧量	265	26	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00005	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0016	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		6	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.06	0.5	mg/L	是	
					粪大肠菌群数		790	1000	个/L	是	
					氨氮	49.3	0.213	5	mg/L	是	
					总氮		13.7	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
动植物油		<0.04	1	mg/L	是						
忻州市	代 县	代县污水处理厂	2017/5/16	城镇污水处理厂污染物排放标准	温度	17.2	17.7				
					PH值		8.24	6-9	无量纲	是	
					生化需氧量		4.1	20	mg/L	是	
					总磷		0.26	1	mg/L	是	
					化学需氧量	390	22	60	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.01	0.05	mg/L	是	
					总砷		0.0039	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		10	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		1400	10000	个/L	是	
					氨氮	40.1	0.522	8	mg/L	是	
					总氮		5.69	20	mg/L	是	
					石油类		0.3	3	mg/L	是	
动植物油		0.38	3	mg/L	是						

忻州市	繁峙县	繁峙县污水处理中心	2017/5/17	城镇污水处理厂污染物排放标准	温度	19	18.7				
					PH值		8.07	6-9	无量纲	是	
					生化需氧量		4.3	20	mg/L	是	
					总磷		0.21	1	mg/L	是	
					化学需氧量	376	21	60	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.008	0.05	mg/L	是	
					总砷		0.004	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		10	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		2200	10000	个/L	是	
					氨氮	40.1	0.203	8	mg/L	是	
					总氮		5.34	20	mg/L	是	
					石油类		0.25	3	mg/L	是	
					动植物油		0.31	3	mg/L	是	
忻州市	宁武县	宁武县城污水处理厂	2017/5/18	城镇污水处理厂污染物排放标准	温度	17.6	17.4				
					PH值		8.16	6-9	无量纲	是	
					生化需氧量		6.8	10	mg/L	是	
					总磷		0.32	0.5	mg/L	是	
					化学需氧量	485	20	50	mg/L	是	
					色度		6	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.009	0.05	mg/L	是	
					总砷		0.0044	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		940	1000	个/L	是	
					氨氮	66	0.233	5	mg/L	是	
					总氮		4.57	15	mg/L	是	
					石油类		0.42	1	mg/L	是	
					动植物油		0.46	1	mg/L	是	

忻州市	静乐县	静乐县污水净化中心	2017/5/24	城镇污水处理厂污染物排放标准	温度	15.6	17.8				
					PH值		8.12	6-9	无量纲	是	
					生化需氧量		6.3	10	mg/L	是	
					总磷		0.33	0.5	mg/L	是	
					化学需氧量	449	30	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.011	0.05	mg/L	是	
					总砷		0.0048	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		790	1000	个/L	是	
					氨氮	47.2	0.566	5	mg/L	是	
					总氮		5.9	15	mg/L	是	
					石油类		0.45	1	mg/L	是	
动植物油		0.51	1	mg/L	是						
忻州市	神池县	神池县污水处理厂	2017/5/24	城镇污水处理厂污染物排放标准	温度	14.6	14.1				
					PH值		8.18	6-9	无量纲	是	
					生化需氧量		4.7	10	mg/L	是	
					总磷		0.28	0.5	mg/L	是	
					化学需氧量	469	21	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.012	0.05	mg/L	是	
					总砷		0.0038	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		940	1000	个/L	是	
					氨氮	49	0.185	5	mg/L	是	
					总氮		5.1	15	mg/L	是	
					石油类		0.36	1	mg/L	是	
动植物油		0.45	1	mg/L	是						

忻州市	五寨县	五寨县污水处理厂	2017/5/23	城镇污水处理厂污染物排放标准	温度	15.2	16.2				
					PH值		8.24	6-9	无量纲	是	
					生化需氧量		5	20	mg/L	是	
					总磷		0.25	1	mg/L	是	
					化学需氧量	423	27	60	mg/L	是	
					色度		6	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.009	0.05	mg/L	是	
					总砷		0.0041	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		10	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		790	10000	个/L	是	
					氨氮	67.5	0.379	8	mg/L	是	
					总氮		4.96	20	mg/L	是	
					石油类		0.36	3	mg/L	是	
					动植物油		0.43	3	mg/L	是	
忻州市	岢岚县	岢岚县城区污水处理厂	2017/5/23	城镇污水处理厂污染物排放标准	温度	15.2	16.3				
					PH值		8.17	6-9	无量纲	是	
					生化需氧量		4.65	20	mg/L	是	
					总磷		0.29	1	mg/L	是	
					化学需氧量	504	22	60	mg/L	是	
					色度		6	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.013	0.05	mg/L	是	
					总砷		0.0043	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		1700	10000	个/L	是	
					氨氮	103	0.404	8	mg/L	是	
					总氮		5.13	20	mg/L	是	
					石油类		0.38	3	mg/L	是	
					动植物油		0.43	3	mg/L	是	

忻州市	河曲县	河曲县城南污水处理厂	2017/5/18	城镇污水处理厂污染物排放标准	温度	18.8	19.5				
					PH值		8.12	6-9	无量纲	是	
					生化需氧量		4.8	10	mg/L	是	
					总磷		0.29	0.5	mg/L	是	
					化学需氧量	583	22	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.011	0.05	mg/L	是	
					总砷		0.0045	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		940	1000	个/L	是	
					氨氮	80.1	0.608	5	mg/L	是	
					总氮		5.96	15	mg/L	是	
					石油类		0.4	1	mg/L	是	
动植物油		0.48	1	mg/L	是						
忻州市	保德县	保德县污水处理站	2017/5/16	城镇污水处理厂污染物排放标准	温度	16.4	16.8				
					PH值		8.23	6-9	无量纲	是	
					生化需氧量		5.1	10	mg/L	是	
					总磷		0.33	0.5	mg/L	是	
					化学需氧量	506	20	50	mg/L	是	
					色度		6	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.012	0.05	mg/L	是	
					总砷		0.0047	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		10	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		940	1000	个/L	是	
					氨氮	66.3	0.455	5	mg/L	是	
					总氮		7.8	15	mg/L	是	
					石油类		0.48	1	mg/L	是	
动植物油		0.54	1	mg/L	是						

忻州市	偏关县	偏关县污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	15.5	17.9				
					PH值		8.02	6-9	无量纲	是	
					生化需氧量		5	20	mg/L	是	
					总磷		0.34	1	mg/L	是	
					化学需氧量	436	23	60	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.03	0.1	mg/L	是	
					六价铬		0.014	0.05	mg/L	是	
					总砷		0.004	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		940	10000	个/L	是	
					氨氮	104	0.562	8	mg/L	是	
					总氮		5.83	20	mg/L	是	
					石油类		0.54	3	mg/L	是	
					动植物油		0.58	3	mg/L	是	
临汾市	尧都区	临汾市第二污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	18.5	18.8				
					PH值	7.69	7.58	6-9	无量纲	是	
					生化需氧量		7.2	10	mg/L	是	
					总磷		0.14	0.5	mg/L	是	
					化学需氧量	419	22	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		0.00011	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0004	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		842	1000	个/L	是	
					氨氮	57.1	0.268	5	mg/L	是	
					总氮		8.06	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
动植物油		<0.04	1	mg/L	是						

临汾市	尧都区	临汾市污水处理厂	2017/5/16	城镇污水处理厂污染物排放标准	温度	15	16.1									
					PH值	7.62	7.87	6-9	无量纲	是						
					生化需氧量		4.6	10	mg/L	是						
					总磷		0.25	0.5	mg/L	是						
					化学需氧量	462	11	50	mg/L	是						
					色度		8	30	倍	是						
					总汞		0.0001	0.001	mg/L	是						
					烷基汞		<0.00001	0	mg/L	是						
					总镉		<0.001	0.01	mg/L	是						
					总铬		<0.004	0.1	mg/L	是						
					六价铬		<0.004	0.05	mg/L	是						
					总砷		0.0006	0.1	mg/L	是						
					总铅		<0.01	0.1	mg/L	是						
					悬浮物		8	10	mg/L	是						
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是						
					粪大肠菌群数		920	1000	个/L	是						
					氨氮	58.9	0.358	5	mg/L	是						
					总氮		7.04	15	mg/L	是						
					临汾市	曲沃县	曲沃县城市污水处理中心	2017/5/19	城镇污水处理厂污染物排放标准	石油类		<0.04	1	mg/L	是	
										动植物油		<0.04	1	mg/L	是	
温度	18.8	19.1														
PH值	7.71	7.91	6-9	无量纲						是						
生化需氧量		4.4	10	mg/L						是						
总磷		0.16	0.5	mg/L						是						
化学需氧量	420	22	50	mg/L						是						
色度		4	30	倍						是						
总汞		0.00012	0.001	mg/L						是						
烷基汞		<0.00001	0	mg/L						是						
总镉		<0.001	0.01	mg/L						是						
总铬		<0.004	0.1	mg/L						是						
六价铬		<0.004	0.05	mg/L						是						
总砷		0.0011	0.1	mg/L						是						
总铅		<0.01	0.1	mg/L						是						
悬浮物		7	10	mg/L						是						
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是						
粪大肠菌群数		630	1000	个/L						是						
氨氮	70.6	1.44	5	mg/L						是						
总氮		9.64	15	mg/L						是						
石油类		0.08	1	mg/L	是											
动植物油		0.06	1	mg/L	是											

临汾市	翼城县	翼城县新源污水处理有限公司	2017/5/18	城镇污水处理厂污染物排放标准	温度	18.3	18.8				
					PH值	7.68	7.79	6-9	无量纲	是	
					生化需氧量		1.8	10	mg/L	是	
					总磷		0.13	0.5	mg/L	是	
					化学需氧量	208	17	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00008	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0006	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		805	1000	个/L	是	
					氨氮	37.9	0.646	5	mg/L	是	
					总氮		3.62	15	mg/L	是	
					石油类		0.07	1	mg/L	是	
					动植物油		<0.04	1	mg/L	是	
临汾市	襄汾县	襄汾县污水处理厂	2017/5/16	城镇污水处理厂污染物排放标准	温度	18.9	18.4				
					PH值	7.43	7.76	6-9	无量纲	是	
					生化需氧量		6.2	10	mg/L	是	
					总磷		0.58	0.5	mg/L	否	0.2
					化学需氧量	246	15	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		0.00017	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0013	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		3800	1000	个/L	否	2.8
					氨氮	52.8	2.74	5	mg/L	是	
					总氮		16.9	15	mg/L	否	0.1
					石油类		<0.04	1	mg/L	是	
					动植物油		0.07	1	mg/L	是	

临汾市	洪洞县	洪洞县晟源污水处理有限公司	2017/5/16	城镇污水处理厂污染物排放标准	温度	18.7	20.1				
					PH值	7.59	7.85	6-9	无量纲	是	
					生化需氧量		4.7	10	mg/L	是	
					总磷		0.06	0.5	mg/L	是	
					化学需氧量	277	15	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00025	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		153	1000	个/L	是	
					氨氮	42.2	4.2	5	mg/L	是	
					总氮		8.52	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
					动植物油		0.05	1	mg/L	是	
临汾市	古 县	古县润民污水处理厂	2017/5/19	城镇污水处理厂污染物排放标准	温度	17.5	19.4				
					PH值	7.74	7.61	6-9	无量纲	是	
					生化需氧量		5.5	20	mg/L	是	
					总磷		0.62	1	mg/L	是	
					化学需氧量	161	13	60	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00017	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0012	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	20	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是	
					粪大肠菌群数		683	10000	个/L	是	
					氨氮	35.8	1.47	8	mg/L	是	
					总氮		9.31	20	mg/L	是	
					石油类		0.06	3	mg/L	是	
					动植物油		0.06	3	mg/L	是	

临汾市	安泽县	安泽县污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	16.7	17.8				
					PH值	7.57	7.86	6-9	无量纲	是	
					生化需氧量		6.8	10	mg/L	是	
					总磷		0.09	0.5	mg/L	是	
					化学需氧量	306	16	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		0.00017	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		843	1000	个/L	是	
					氨氮	61.1	2.69	5	mg/L	是	
					总氮		5.38	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
					动植物油	16.7	<0.04	1	mg/L	是	
临汾市	浮山县	浮山县污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	15	14.4				
					PH值	7.59	8.14	6-9	无量纲	是	
					生化需氧量		2.2	10	mg/L	是	
					总磷		0.07	0.5	mg/L	是	
					化学需氧量	330	31	50	mg/L	是	
					色度		2	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		400	1000	个/L	是	
					氨氮	74.6	3.91	5	mg/L	是	
					总氮		9.13	15	mg/L	是	
					石油类		<0.04	1	mg/L	是	
					动植物油		<0.04	1	mg/L	是	

临汾市	吉 县	吉县污水处理厂	2017/5/19	城镇污水处理厂污染物排放标准	温度	17.7	17.8									
					PH值	7.72	8.01	6-9	无量纲	是						
					生化需氧量		6.2	10	mg/L	是						
					总磷		0.34	0.5	mg/L	是						
					化学需氧量	157	14	50	mg/L	是						
					色度		4	30	倍	是						
					总汞		0.00017	0.001	mg/L	是						
					烷基汞		<0.00001	0	mg/L	是						
					总镉		<0.001	0.01	mg/L	是						
					总铬		<0.004	0.1	mg/L	是						
					六价铬		<0.004	0.05	mg/L	是						
					总砷		<0.0003	0.1	mg/L	是						
					总铅		<0.01	0.1	mg/L	是						
					悬浮物		9	10	mg/L	是						
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是						
					粪大肠菌群数		483	1000	个/L	是						
					氨氮	30.4	0.274	5	mg/L	是						
					总氮		4.76	15	mg/L	是						
					临汾市	乡宁县	乡宁县城城区污水处理厂	2017/5/18	城镇污水处理厂污染物排放标准	石油类		0.1	1	mg/L	是	
										动植物油		<0.04	1	mg/L	是	
温度	17.7	18.3														
PH值	7.77	7.89	6-9	无量纲						是						
生化需氧量		5.7	10	mg/L						是						
总磷		0.48	0.5	mg/L						是						
化学需氧量	262	15	50	mg/L						是						
色度		4	30	倍						是						
总汞		0.00011	0.001	mg/L						是						
烷基汞		<0.00001	0	mg/L						是						
总镉		<0.001	0.01	mg/L						是						
总铬		<0.004	0.1	mg/L						是						
六价铬		<0.004	0.05	mg/L						是						
总砷		0.0006	0.1	mg/L						是						
总铅		<0.01	0.1	mg/L						是						
悬浮物		6	10	mg/L						是						
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是						
粪大肠菌群数		705	1000	个/L						是						
氨氮	52.2	0.226	5	mg/L						是						
总氮		9.81	15	mg/L						是						
石油类		0.05	1	mg/L	是											
动植物油		0.09	1	mg/L	是											

临汾市	大宁县	大宁县新昕污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	16.4	18				
					PH值	7.8	7.91	6-9	无量纲	是	
					生化需氧量		9	10	mg/L	是	
					总磷		0.44	0.5	mg/L	是	
					化学需氧量	278	34	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		0.00014	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0013	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是	
					粪大肠菌群数		196	1000	个/L	是	
					氨氮	38.7	3.67	5	mg/L	是	
					总氮		13.4	15	mg/L	是	
					石油类		0.18	1	mg/L	是	
					动植物油		<0.04	1	mg/L	是	
临汾市	隰县	隰县污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	温度	15.5	18				
					PH值	7.66	8.07	6-9	无量纲	是	
					生化需氧量		8.4	10	mg/L	是	
					总磷		0.36	0.5	mg/L	是	
					化学需氧量	530	30	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		0.00013	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0009	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.06	0.5	mg/L	是	
					粪大肠菌群数		322	1000	个/L	是	
					氨氮	88.6	3.99	5	mg/L	是	
					总氮		13.4	15	mg/L	是	
					石油类		0.13	1	mg/L	是	
					动植物油		0.08	1	mg/L	是	

临汾市	永和县	永和县洁丽服务有限公司	2017/5/16	城镇污水处理厂污染物排放标准	温度	18.2	18									
					PH值	7.62	7.86	6-9	无量纲	是						
					生化需氧量		5	10	mg/L	是						
					总磷		0.12	0.5	mg/L	是						
					化学需氧量	303	14	50	mg/L	是						
					色度		4	30	倍	是						
					总汞		0.00004	0.001	mg/L	是						
					烷基汞		<0.00001	0	mg/L	是						
					总镉		<0.001	0.01	mg/L	是						
					总铬		<0.004	0.1	mg/L	是						
					六价铬		<0.004	0.05	mg/L	是						
					总砷		0.0006	0.1	mg/L	是						
					总铅		<0.01	0.1	mg/L	是						
					悬浮物		8	10	mg/L	是						
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是						
					粪大肠菌群数		842	1000	个/L	是						
					氨氮	62.1	1.29	5	mg/L	是						
					总氮		7.16	15	mg/L	是						
					临汾市	蒲 县	蒲县城区污水处理厂	2017/5/17	城镇污水处理厂污染物排放标准	石油类		<0.04	1	mg/L	是	
										动植物油		0.05	1	mg/L	是	
温度	14.6	16.6														
PH值	7.85	7.74	6-9	无量纲						是						
生化需氧量		12.5	20	mg/L						是						
总磷		2.14	1	mg/L						否	1.1					
化学需氧量	208	30	60	mg/L						是						
色度		4	30	倍						是						
总汞		0.00028	0.001	mg/L						是						
烷基汞		<0.00001	0	mg/L						是						
总镉		<0.001	0.01	mg/L						是						
总铬		<0.004	0.1	mg/L						是						
六价铬		<0.004	0.05	mg/L						是						
总砷		0.0014	0.1	mg/L						是						
总铅		<0.01	0.1	mg/L						是						
悬浮物		8	20	mg/L						是						
阴离子表面活性剂 (LAS)		0.13	1	mg/L						是						
粪大肠菌群数		558	10000	个/L						是						
氨氮	30	6.2	8	mg/L						是						
总氮		30.2	20	mg/L						否	0.5					
石油类		0.88	3	mg/L	是											
动植物油		0.22	3	mg/L	是											

临汾市	汾西县	汾西县污水处理厂	2017/5/18	城镇污水处理厂污染物排放标准	温度	17.3	19.4				
					PH值	7.78	7.69	6-9	无量纲	是	
					生化需氧量		8.5	10	mg/L	是	
					总磷		0.49	0.5	mg/L	是	
					化学需氧量	280	20	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		0.00032	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0023	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		7	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.09	0.5	mg/L	是	
					粪大肠菌群数		728	1000	个/L	是	
					氨氮	52	1.04	5	mg/L	是	
					总氮		2.82	15	mg/L	是	
					石油类		0.07	1	mg/L	是	
					动植物油		0.05	1	mg/L	是	
临汾市	侯马市	侯马市政通污水处理有限责任公司	2017/5/17	城镇污水处理厂污染物排放标准	温度	17.4	17.9				
					PH值	7.67	8.02	6-9	无量纲	是	
					生化需氧量		2.6	10	mg/L	是	
					总磷		0.48	0.5	mg/L	是	
					化学需氧量	318	22	50	mg/L	是	
					色度		4	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					烷基汞		<0.00001	0	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		<0.004	0.05	mg/L	是	
					总砷		0.0006	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		9	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.06	0.5	mg/L	是	
					粪大肠菌群数		168	1000	个/L	是	
					氨氮	78	1.45	5	mg/L	是	
					总氮		6.15	15	mg/L	是	
					石油类		0.05	1	mg/L	是	
					动植物油		<0.04	1	mg/L	是	

临汾市	霍州市	霍州市朝阳污水净化有限责任公司	2017/5/19	城镇污水处理厂污染物排放标准	温度	17.3	19.5									
					PH值	7.6	7.95	6-9	无量纲	是						
					生化需氧量		2.8	10	mg/L	是						
					总磷		0.19	0.5	mg/L	是						
					化学需氧量	360	8	50	mg/L	是						
					色度		4	30	倍	是						
					总汞		0.00006	0.001	mg/L	是						
					烷基汞		<0.00001	0	mg/L	是						
					总镉		<0.001	0.01	mg/L	是						
					总铬		<0.004	0.1	mg/L	是						
					六价铬		<0.004	0.05	mg/L	是						
					总砷		<0.0003	0.1	mg/L	是						
					总铅		<0.01	0.1	mg/L	是						
					悬浮物		9	10	mg/L	是						
					阴离子表面活性剂 (LAS)		0.06	0.5	mg/L	是						
					粪大肠菌群数		81	1000	个/L	是						
					氨氮	48	0.319	5	mg/L	是						
					总氮		2.04	15	mg/L	是						
					吕梁市	兴县	兴县县城污水处理厂	2017/5/16	城镇污水处理厂污染物排放标准	石油类		<0.04	1	mg/L	是	
										动植物油		0.05	1	mg/L	是	
温度	15.8	16.4														
PH值	7.61	7.36	6-9	无量纲						是						
生化需氧量		9.2	10	mg/L						是						
总磷		0.36	0.5	mg/L						是						
化学需氧量	445	45	50	mg/L						是						
色度		12	30	倍						是						
总汞		<0.00004	0.001	mg/L						是						
总镉		<0.001	0.01	mg/L						是						
总铬		<0.004	0.1	mg/L						是						
六价铬		0.005	0.05	mg/L						是						
总砷		<0.0003	0.1	mg/L						是						
总铅		<0.01	0.1	mg/L						是						
悬浮物		8	10	mg/L						是						
阴离子表面活性剂 (LAS)		0.41	0.5	mg/L						是						
粪大肠菌群数		745	1000	个/L						是						
氨氮	29.6	2.95	5	mg/L						是						
总氮		12.5	15	mg/L						是						
石油类		0.119	1	mg/L						是						
动植物油		0.141	1	mg/L	是											

吕梁市	临县	临县新民污水处理有限公司	2017/5/17	城镇污水处理厂污染物排放标准	温度	15	18.3				
					PH值	7.69	7.49	6-9	无量纲	是	
					生化需氧量		9.4	10	mg/L	是	
					总磷		0.35	0.5	mg/L	是	
					化学需氧量	440	45	50	mg/L	是	
					色度		16	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.005	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.42	0.5	mg/L	是	
					粪大肠菌群数		690	1000	个/L	是	
					氨氮	29.2	2.7	5	mg/L	是	
					总氮		13.5	15	mg/L	是	
					石油类		0.134	1	mg/L	是	
					动植物油		0.182	1	mg/L	是	
吕梁市	柳林县	山西华光发电有限责任公司 (柳林县污水处理厂)	2017/5/15	城镇污水处理厂污染物排放标准	温度	19.3	18.7				
					PH值	7.64	7.39	6-9	无量纲	是	
					生化需氧量		9.1	10	mg/L	是	
					总磷		0.31	0.5	mg/L	是	
					化学需氧量	400	46	50	mg/L	是	
					色度		12	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.006	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.42	0.5	mg/L	是	
					粪大肠菌群数		805	1000	个/L	是	
					氨氮	28.2	2.65	5	mg/L	是	
					总氮		12.2	15	mg/L	是	
					石油类		0.116	1	mg/L	是	
					动植物油		0.141	1	mg/L	是	

吕梁市	石楼县	石楼县清环污水处理有限责任公司	2017/5/19	城镇污水处理厂污染物排放标准	温度	14.9	15.4				
					PH值	7.62	7.34	6-9	无量纲	是	
					生化需氧量		8.9	10	mg/L	是	
					总磷		0.36	0.5	mg/L	是	
					化学需氧量	448	44	50	mg/L	是	
					色度		8	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.005	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.41	0.5	mg/L	是	
					粪大肠菌群数		700	1000	个/L	是	
					氨氮	30.2	4.27	5	mg/L	是	
					总氮		12.1	15	mg/L	是	
					石油类		0.126	1	mg/L	是	
动植物油		0.152	1	mg/L	是						
吕梁市	方山县	方山县污水处理厂	2017/5/19	城镇污水处理厂污染物排放标准	温度	15	15.4				
					PH值	7.69	7.49	6-9	无量纲	是	
					生化需氧量		8.8	10	mg/L	是	
					总磷		0.31	0.5	mg/L	是	
					化学需氧量	439	45	50	mg/L	是	
					色度		16	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.005	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.4	0.5	mg/L	是	
					粪大肠菌群数		510	1000	个/L	是	
					氨氮	28.4	2.55	5	mg/L	是	
					总氮		12.1	15	mg/L	是	
					石油类		0.133	1	mg/L	是	
动植物油		0.173	1	mg/L	是						

吕梁市	孝义市	山西汾西矿业（集团）有限责任公司高阳煤矿生活污水处理厂	2017/5/28	城镇污水处理厂污染物排放标准	温度	22.6	22.7				
					PH值	7.62	7.42	6-9	无量纲	是	
					生化需氧量		8.6	10	mg/L	是	
					总磷		0.32	0.5	mg/L	是	
					化学需氧量	399	41	50	mg/L	是	
					色度		16	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.006	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂（LAS）		0.43	0.5	mg/L	是	
					粪大肠菌群数		865	1000	个/L	是	
					氨氮	28.2	2.8	5	mg/L	是	
					总氮		13.2	15	mg/L	是	
					石油类		0.136	1	mg/L	是	
动植物油		0.152	1	mg/L	是						
吕梁市	孝义市	孝义市第二污水处理厂	2017/5/28	城镇污水处理厂污染物排放标准	温度	20.8	23.4				
					PH值	7.66	7.46	6-9	无量纲	是	
					生化需氧量		8.5	10	mg/L	是	
					总磷		0.34	0.5	mg/L	是	
					化学需氧量	403	40	50	mg/L	是	
					色度		12	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.005	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂（LAS）		0.39	0.5	mg/L	是	
					粪大肠菌群数		578	1000	个/L	是	
					氨氮	27.1	1.72	5	mg/L	是	
					总氮		12.7	15	mg/L	是	
					石油类		0.133	1	mg/L	是	
动植物油		0.153	1	mg/L	是						

吕梁市	孝义市	孝义市华博水务有限公司	2017/5/28	城镇污水处理厂污染物排放标准	温度	22.2	22.8				
					PH值	7.67	7.46	6-9	无量纲	是	
					生化需氧量		5.7	10	mg/L	是	
					总磷		0.35	0.5	mg/L	是	
					化学需氧量	391	32	50	mg/L	是	
					色度		12	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.005	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.41	0.5	mg/L	是	
					粪大肠菌群数		535	1000	个/L	是	
					氨氮	27.1	1.79	5	mg/L	是	
					总氮		12.9	15	mg/L	是	
					石油类		0.12	1	mg/L	是	
动植物油		0.132	1	mg/L	是						
吕梁市	汾阳市	汾阳市国峰污水处理厂有限公司	2017/5/18	城镇污水处理厂污染物排放标准	温度	18.2	18.3				
					PH值	7.69	7.48	6-9	无量纲	是	
					生化需氧量		8.9	10	mg/L	是	
					总磷		0.3	0.5	mg/L	是	
					化学需氧量	436	45	50	mg/L	是	
					色度		12	30	倍	是	
					总汞		<0.00004	0.001	mg/L	是	
					总镉		<0.001	0.01	mg/L	是	
					总铬		<0.004	0.1	mg/L	是	
					六价铬		0.006	0.05	mg/L	是	
					总砷		<0.0003	0.1	mg/L	是	
					总铅		<0.01	0.1	mg/L	是	
					悬浮物		8	10	mg/L	是	
					阴离子表面活性剂 (LAS)		0.41	0.5	mg/L	是	
					粪大肠菌群数		665	1000	个/L	是	
					氨氮	28.6	3.14	5	mg/L	是	
					总氮		12.9	15	mg/L	是	
					石油类		0.133	1	mg/L	是	
动植物油		0.24	1	mg/L	是						
签发:		审核:		第 页/共 页							