

表3：2013年第2季度山西省国家重点监控企业污水处理厂监督性监测结果

行政区 (市)	行政区 (县/区)	污水处理厂 名称	监测日期	执行标准名称	监测项目	进口浓度 (mg/L)	出口浓度 (mg/L)	标准限值 (mg/L)	排放单位	是否达标	超标倍数	备注
太原市	小店区	太原市豪峰 污水处理有 限公司	2013-4-15	城镇污水处理厂 污染物排放标准	温度	15.4	16.6					
					PH值	7.62	7.42	6-9	无量纲	是		
					生化需氧量	145	6.66	30	mg/L	是		
					总磷	5.24	0.254	3	mg/L	是		
					化学需氧量	278	23	100	mg/L	是		
					色度	250	5	40	倍	是		
					总汞	0.000344	0.000093	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.019	0.006	0.1	mg/L	是		
					六价铬	0.006	<0.004	0.05	mg/L	是		
					总砷	0.00229	0.000458	0.1	mg/L	是		
					总铅	0.056	<0.016	0.1	mg/L	是		
					悬浮物	142	6	30	mg/L	是		
					阴离子表面活性剂 (LAS)	1.08	0.133	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	44.8	0.062	25	mg/L	是		
					总氮	49.7	9		mg/L			
石油类	8.25	0.12	5	mg/L	是							
动植物油	5.44	0.07	5	mg/L	是							
太原市	尖草坪区	太钢尖草坪 污水处理厂	2013-4-16	城镇污水处理厂 污染物排放标准	温度	15.9	16.8					
					PH值	7.8	7.2	6-9	无量纲	是		
					生化需氧量	123	14.6	30	mg/L	是		
					总磷	3.88	0.938	3	mg/L	是		
					化学需氧量	214	23.9	100	mg/L	是		
					色度	50	5	40	倍	是		
					总汞	0.000236	0.000067	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.032	0.015	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0034	0.000655	0.1	mg/L	是		
					总铅	0.151	<0.016	0.1	mg/L	是		
					悬浮物	137	6	30	mg/L	是		
					阴离子表面活性剂 (LAS)	1.01	0.146	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	36.2	2.69	25	mg/L	是		

					总氮	53.4	14.3		mg/L			
					石油类	3.91	0.12	5	mg/L	是		
					动植物油	2.02	0.07	5	mg/L	是		
太原市	尖草坪区	太原市排水管理处污水净化二厂	2013-4-16	城镇污水处理厂污染物排放标准	温度	17.4	11.1					
					PH值	7.22	7.57	6-9	无量纲	是		
					生化需氧量	155	1.84	30	mg/L	是		
					总磷	7.48	0.37	3	mg/L	是		
					化学需氧量	338	35.2	100	mg/L	是		
					色度	100	5	40	倍	是		
					总汞	0.000348	0.00008	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.018	0.01	0.1	mg/L	是		
					六价铬	0.005	<0.004	0.05	mg/L	是		
					总砷	0.00183	0.000591	0.1	mg/L	是		
					总铅	0.058	<0.016	0.1	mg/L	是		
					悬浮物	146	7	30	mg/L	是		
					阴离子表面活性剂 (LAS)	0.93	0.153	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	62.9	1.96	30	mg/L	是		
					总氮	73.8	6.92		mg/L			
					石油类	3.71	0.11	5	mg/L	是		
					动植物油	2.82	0.08	5	mg/L	是		
					太原市	万柏林区	太原朗新明污水处理有限公司	2013-4-11	城镇污水处理厂污染物排放标准	温度	13.1	11.3
PH值	7.4	7.2	6-9	无量纲						是		
生化需氧量	148	1.4	30	mg/L						是		
总磷	6.47	0.028	3	mg/L						是		
化学需氧量	255	26	100	mg/L						是		
色度	500	5	40	倍						是		
总汞	0.000176	0.000085	0.001	mg/L						是		
总镉	<0.002	<0.002	0.01	mg/L						是		
总铬	0.014	0.006	0.1	mg/L						是		
六价铬	0.004	<0.004	0.05	mg/L						是		
总砷	0.00145	0.000565	0.1	mg/L						是		
总铅	0.096	<0.016	0.1	mg/L						是		
悬浮物	146	8	30	mg/L						是		
阴离子表面活性剂 (LAS)	1.23	0.162	2	mg/L						是		
粪大肠菌群数	240000	<2	10000	个/L						是		
氨氮	50.3	0.289	30	mg/L						是		
总氮	59.7	12.6		mg/L								
石油类	5.66	0.09	5	mg/L						是		

太原市	晋源区	太原化学工业集团有限公司南堰污水处理分公司（水源分公司）	2013-4-8	城镇污水处理厂污染物排放标准	动植物油	5.6	0.1	5	mg/L	是		
					温度	13.8	14.8					
					PH值	7.21	7.22	6-9	无量纲	是		
					生化需氧量	115	15.6	30	mg/L	是		
					总磷	7.06	1.3	3	mg/L	是		
					化学需氧量	226	28	100	mg/L	是		
					色度	100	10	40	倍	是		
					总汞	0.000185	0.000094	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.007	0.004	0.1	mg/L	是		
					六价铬	0.004	<0.004	0.05	mg/L	是		
					总砷	0.0029	0.00156	0.1	mg/L	是		
					总铅	0.105	<0.016	0.1	mg/L	是		
					悬浮物	300	7	30	mg/L	是		
					阴离子表面活性剂（LAS）	0.915	0.236	2	mg/L	是		
					粪大肠菌群数	240000	7000	10000	个/L	是		
					氨氮	50.3	22.8	25	mg/L	是		
					总氮	65.4	31		mg/L			
					石油类	4.68	0.1	5	mg/L	是		
太原市	清徐县	清徐县住房和城乡建设管理局	2013-4-11	城镇污水处理厂污染物排放标准	动植物油	2.19	0.08	5	mg/L	是		
					温度	13.7	12.4					
					PH值	7.65	7.2	6-9	无量纲	是		
					生化需氧量	49.4	8.77	30	mg/L	是		
					总磷	6.31	0.148	3	mg/L	是		
					化学需氧量	84.9	14.4	100	mg/L	是		
					色度	100	5	40	倍	是		
					总汞	0.000197	0.000056	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.027	0.021	0.1	mg/L	是		
					六价铬	0.006	<0.004	0.05	mg/L	是		
					总砷	0.00121	0.00079	0.1	mg/L	是		
					总铅	0.1	<0.016	0.1	mg/L	是		
					悬浮物	131	8	30	mg/L	是		
					阴离子表面活性剂（LAS）	1.01	0.172	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	37	1.9	25	mg/L	是		
					总氮	38.4	14.6		mg/L			
					石油类	4.08	0.14	5	mg/L	是		
动植物油	2.48	0.08	5	mg/L	是							
				温度	12	11.5						

太原市	阳曲县	阳曲县青龙污水处理有限公司	2013-4-9	城镇污水处理厂污染物排放标准	PH值	7.76	7.3	6-9	无量纲	是		
					生化需氧量	132	1.38	10	mg/L	是		
					总磷	2.5	0.068	0.5	mg/L	是		
					化学需氧量	246	12.6	50	mg/L	是		
					色度	50	5	30	倍	是		
					总汞	0.000236	0.000067	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.014	0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.00104	0.000646	0.1	mg/L	是		
					总铅	0.048	<0.016	0.1	mg/L	是		
					悬浮物	166	7	10	mg/L	是		
					阴离子表面活性剂 (LAS)	0.874	0.159	0.5	mg/L	是		
					粪大肠菌群数	240000	230	1000	个/L	是		
					氨氮	27.2	0.279	8	mg/L	是		
					总氮	37.5	11.7	15	mg/L	是		
					石油类	4.03	0.11	1	mg/L	是		
动植物油	2.75	0.07	1	mg/L	是							
太原市	娄烦县	山西(娄烦)正阳水净化有限公司	2013-4-22	城镇污水处理厂污染物排放标准	温度	12.7	12.8					
					PH值	7.5	7.48	6-9	无量纲	是		
					生化需氧量	292	1.59	30	mg/L	是		
					总磷	7.02	0.066	3	mg/L	是		
					化学需氧量	455	12.9	100	mg/L	是		
					色度	50	5	40	倍	是		
					总汞	0.000236	0.000066	0.001	mg/L	是		
					总镉	0.002	<0.002	0.01	mg/L	是		
					总铬	0.027	0.016	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.00103	0.000527	0.1	mg/L	是		
					总铅	0.04	0.023	0.1	mg/L	是		
					悬浮物	138	6	30	mg/L	是		
					阴离子表面活性剂 (LAS)	2.14	0.348	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	54	0.126	25	mg/L	是		
					总氮	59.1	2.44		mg/L			
石油类	4.11	0.1	5	mg/L	是							
动植物油	2.19	0.06	5	mg/L	是							
					温度	16	12.5					
					石油类	4.47	0.11	5	mg/L	是		
					动植物油	1.59	0.07	5	mg/L	是		

太原市	太原市经济技术开发区	太原金世纪阳光水净化有限公司	2013-4-8	城镇污水处理厂污染物排放标准	PH值	7.63	7.25	6-9	无量纲	是		
					生化需氧量	104	1.23	30	mg/L	是		
					总磷	34.2	0.308	3	mg/L	是		
					化学需氧量	185	8.4	100	mg/L	是		
					色度	50	5	40	倍	是		
					总汞	0.000184	0.000057	0.001	mg/L	是		
					总镉	<0.002	<0.002	0.01	mg/L	是		
					总铬	0.016	0.01	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.00168	0.000724	0.1	mg/L	是		
					总铅	0.105	<0.016	0.1	mg/L	是		
					悬浮物	300	8	30	mg/L	是		
					阴离子表面活性剂 (LAS)	1.24	0.144	2	mg/L	是		
					粪大肠菌群数	240000	<2	10000	个/L	是		
					氨氮	29.9	3.65	25	mg/L	是		
					总氮	37.9	14.8		mg/L			
					太原市	古交市	山西西山煤电股份有限公司镇城底矿污水厂	2013-4-24	城镇污水处理厂污染物排放标准	温度	14.5	16.4
PH值	7.5	7.28	6-9	无量纲						是		
生化需氧量	111	8.25	30	mg/L						是		
总磷	2.64	1.05	3	mg/L						是		
化学需氧量	223	43.5	100	mg/L						是		
色度	50	5	40	倍						是		
总汞	0.000707	0.000092	0.001	mg/L						是		
总镉	0.004	<0.002	0.01	mg/L						是		
总铬	0.024	0.011	0.1	mg/L						是		
六价铬	0.004	<0.004	0.05	mg/L						是		
总砷	0.00311	0.000567	0.1	mg/L						是		
总铅	0.026	<0.016	0.1	mg/L						是		
悬浮物	53	9	30	mg/L						是		
阴离子表面活性剂 (LAS)	0.976	0.106	2	mg/L						是		
粪大肠菌群数	240000	160000	10000	个/L						否	15	
氨氮	12.1	2.92	25	mg/L						是		
总氮	34.5	12.7		mg/L								
石油类	4.28	0.11	5	mg/L	是							
动植物油	2.38	0.06	5	mg/L	是							
					温度	15.3	18.2					
					PH值	8.14	7.65	6-9	无量纲	是		
					生化需氧量	97.2	9.48	30	mg/L	是		
					总磷	1.99	0.512	3	mg/L	是		
					化学需氧量	195	48.1	100	mg/L	是		

太原市	古交市	山西西山煤气化有限责任公司污水处理厂	2013-4-24	城镇污水处理厂污染物排放标准	色度	500	5	40	倍	是		
					总汞	0.000418	0.000065	0.001	mg/L	是		
					总镉	0.026	0.008	0.01	mg/L	是		
					总铬	0.024	0.014	0.1	mg/L	是		
					六价铬	0.006	<0.004	0.05	mg/L	是		
					总砷	0.00249	0.00086	0.1	mg/L	是		
					总铅	0.18	0.093	0.1	mg/L	是		
					悬浮物	85	10	30	mg/L	是		
					阴离子表面活性剂 (LAS)	0.548	0.061	2	mg/L	是		
					粪大肠菌群数	240000	160000	10000	个/L	否	15	
					氨氮	21.4	3.09	25	mg/L	是		
					总氮	26.5	8.5		mg/L			
					石油类	1.98	0.09	5	mg/L	是		
					动植物油	1.78	0.07	5	mg/L	是		
					太原市	古交市	西山煤电(集团)有限公司古交给排水分公司	2013-4-24	城镇污水处理厂污染物排放标准	温度	15.3	16.9
PH值	7.53	7.21	6-9	无量纲						是		
生化需氧量	121	7.9	30	mg/L						是		
总磷	5.7	1.59	3	mg/L						是		
化学需氧量	241	40.5	100	mg/L						是		
色度	500	10	40	倍						是		
总汞	0.000838	0.000064	0.001	mg/L						是		
总镉	0.02	0.006	0.01	mg/L						是		
总铬	0.017	0.01	0.1	mg/L						是		
六价铬	0.006	<0.004	0.05	mg/L						是		
总砷	0.00141	0.00068	0.1	mg/L						是		
总铅	0.166	0.088	0.1	mg/L						是		
悬浮物	241	10	30	mg/L						是		
阴离子表面活性剂 (LAS)	0.69	0.117	2	mg/L						是		
粪大肠菌群数	240000	160000	10000	个/L						否	15	
氨氮	12.9	4.37	25	mg/L	是							
总氮	58.4	19.7		mg/L								
石油类	5.11	0.13	5	mg/L	是							
动植物油	2.21	0.06	5	mg/L	是							
					温度	18.7	20.4					
					阴离子表面活性剂 (LAS)		0.147	1	mg/L	是		
					粪大肠菌群数		9800	10000	个/L	是		
					氨氮	79	0.993	8	mg/L	是		
					总氮		5.09	20	mg/L	是		
					石油类		<0.04	3	mg/L	是		
动植物油		0.07	3	mg/L	是							

大同市	城 区	大同市西郊污水处理厂	2013-5-7	城镇污水处理厂污染物排放标准	总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.002	0.1	mg/L	是		
					总铅		0.002	0.1	mg/L	是		
					悬浮物	255	18	20	mg/L	是		
					PH值		7.73	6-9	无量纲	是		
					生化需氧量	272	10	20	mg/L	是		
					总磷	10.1	0.34	1.5	mg/L	是		
					化学需氧量	402	42.8	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.0002	0.001	mg/L	是		
					大同市	矿 区	大同煤矿集团有限责任公司生活污水处理分公司	2013-5-23	城镇污水处理厂污染物排放标准	温度	21	21.2
PH值		7.09	6-9	无量纲						是		
生化需氧量	210	12	20	mg/L						是		
总磷	3.86	0.87	1	mg/L						是		
化学需氧量	334	47.7	60	mg/L						是		
色度		5	30	倍						是		
总汞		0.00049	0.001	mg/L						是		
总镉		<0.0001	0.01	mg/L						是		
总铬		<0.005	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		0.0052	0.1	mg/L						是		
总铅		0.002	0.1	mg/L						是		
悬浮物	209	19	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.205	1	mg/L						是		
粪大肠菌群数		250	10000	个/L						是		
氨氮	88.6	7.86	8	mg/L						是		
总氮		19.3	20	mg/L						是		
石油类		0.09	3	mg/L						是		
动植物油		0.21	3	mg/L	是							
		大同市东郊		城镇污水处理厂	温度	21.8	19.3					
					PH值		7.89	6-9	无量纲	是		
					生化需氧量	278	12	20	mg/L	是		
					总磷	9.82	0.87	1.5	mg/L	是		
					化学需氧量	406	40	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00026	0.001	mg/L	是		
					总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		

大同市	南郊区	大同市南郊污水处理厂	2013-5-28	城镇污水处理厂污染物排放标准	六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0015	0.1	mg/L	是		
					总铅		<0.001	0.1	mg/L	是		
					悬浮物	374	14	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.186	1	mg/L	是		
					粪大肠菌群数		300	10000	个/L	是		
					氨氮	69	7.79	8	mg/L	是		
					总氮		14.9	20	mg/L	是		
					石油类		0.06	3	mg/L	是		
					动植物油		0.17	3	mg/L	是		
大同市	新荣区	大同市新荣区污水处理厂	2013-5-9	城镇污水处理厂污染物排放标准	温度	12.3	15.6					
					阴离子表面活性剂 (LAS)		0.171	0.5	mg/L	是		
					粪大肠菌群数		140000	1000	个/L	否	139	
					氨氮	42.8	13.5	5	mg/L	否	1.7	
					总氮		23.2	15	mg/L	否	0.5	
					石油类		0.07	1	mg/L	是		
					动植物油		0.08	1	mg/L	是		
					总镉		0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0041	0.1	mg/L	是		
					总铅		0.001	0.1	mg/L	是		
					悬浮物	396	10	10	mg/L	是		
					PH值		7.52	6-9	无量纲	是		
					生化需氧量	119	11	10	mg/L	否	0.1	
					总磷	4.32	0.45	0.5	mg/L	是		
					化学需氧量	200	46.1	50	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00026	0.001	mg/L	是		
大同市	阳高县	阳高县污水处理厂	2013-5-6	城镇污水处理厂污染物排放标准	温度	16	18.1					
					PH值		7.33	6-9	无量纲	是		
					生化需氧量	156	4	20	mg/L	是		
					总磷	6.92	0.84	1	mg/L	是		
					化学需氧量	254	19.6	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00017	0.001	mg/L	是		
					总镉		0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
总砷		0.0025	0.1	mg/L	是							

					总铅		0.009	0.1	mg/L	是		
					悬浮物	222	15	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.112	1	mg/L	是		
					粪大肠菌群数		720	10000	个/L	是		
					氨氮	29.4	3.67	8	mg/L	是		
					总氮		18.4	20	mg/L	是		
					石油类		0.32	3	mg/L	是		
					动植物油		0.3	3	mg/L	是		
大同市	天镇县	天镇县源洁污水处理有限公司	2013-5-6	城镇污水处理厂污染物排放标准	温度	18	16.2					
					PH值		7.42	6-9	无量纲	是		
					生化需氧量	183	8	20	mg/L	是		
					总磷	4.94	0.88	1	mg/L	是		
					化学需氧量	293	39.2	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00022	0.001	mg/L	是		
					总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.003	0.1	mg/L	是		
					总铅		0.002	0.1	mg/L	是		
					悬浮物	118	14	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.134	1	mg/L	是		
					粪大肠菌群数		880	10000	个/L	是		
					氨氮	40.7	0.577	8	mg/L	是		
					总氮		19.7	20	mg/L	是		
石油类		0.24	3	mg/L	是							
动植物油		0.92	3	mg/L	是							
大同市	广灵县	广灵县城污水处理厂	2013-5-13	城镇污水处理厂污染物排放标准	温度	14.5	17					
					PH值		7.32	6-9	无量纲	是		
					生化需氧量	142	8	20	mg/L	是		
					总磷	6.54	0.92	1	mg/L	是		
					化学需氧量	236	40.6	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00007	0.001	mg/L	是		
					总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0031	0.1	mg/L	是		
					总铅		0.002	0.1	mg/L	是		
					悬浮物	452	20	20	mg/L	是		

					阴离子表面活性剂 (LAS)		0.178	1	mg/L	是		
					粪大肠菌群数		9000	10000	个/L	是		
					氨氮	35.5	1.54	8	mg/L	是		
					总氮		19	20	mg/L	是		
					石油类		0.06	3	mg/L	是		
					动植物油		0.08	3	mg/L	是		
					温度	20.5	21.6					
大同市	灵丘县	灵丘县污水处理厂	2013-5-27	城镇污水处理厂污染物排放标准	阴离子表面活性剂 (LAS)		0.105	0.5	mg/L	是		
					粪大肠菌群数		800	1000	个/L	是		
					氨氮	78.4	3.96	5	mg/L	是		
					总氮		14.1	15	mg/L	是		
					石油类		<0.04	1	mg/L	是		
					动植物油		0.16	1	mg/L	是		
					总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0027	0.1	mg/L	是		
					总铅		<0.001	0.1	mg/L	是		
					悬浮物	263	10	10	mg/L	是		
					PH值		7.32	6-9	无量纲	是		
					生化需氧量	172	6	10	mg/L	是		
					总磷	7.65	0.35	0.5	mg/L	是		
					化学需氧量	324	28.6	50	mg/L	是		
					色度		5	30	倍	是		
总汞		0.00022	0.001	mg/L	是							
					温度	18.2	17.6					
大同市	浑源县	浑源县污水处理厂	2013-5-27	城镇污水处理厂污染物排放标准	阴离子表面活性剂 (LAS)		0.142	1	mg/L	是		
					粪大肠菌群数		600	10000	个/L	是		
					氨氮	37.6	7.91	8	mg/L	是		
					总氮		19.7	20	mg/L	是		
					石油类		<0.04	3	mg/L	是		
					动植物油		0.2	3	mg/L	是		
					总镉		<0.0001	0.01	mg/L	是		
					总铬		<0.005	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0028	0.1	mg/L	是		
					总铅		0.001	0.1	mg/L	是		
					悬浮物	218	16	20	mg/L	是		
					PH值		7.17	6-9	无量纲	是		
					生化需氧量	188	7	20	mg/L	是		

					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	399	17	20	mg/L	是		
					PH值	7.77	8.06	6-9	无量纲	是		闭路循环
					生化需氧量	19.4	2.7	20	mg/L	是		闭路循环
					总磷	3.32	0.32	1.5	mg/L	是		闭路循环
					化学需氧量	110	29.4	60	mg/L	是		闭路循环
					色度	4	1	30	倍	是		闭路循环
					总汞	<0.00001	<0.00001	0.001	mg/L	是		闭路循环
					总镉	<0.001	<0.001	0.01	mg/L	是		闭路循环
					总铬	<0.004	<0.004	0.1	mg/L	是		闭路循环
					六价铬	<0.004	<0.004	0.05	mg/L	是		闭路循环
					总砷	0.0025	<0.0005	0.1	mg/L	是		闭路循环
					总铅	<0.01	<0.01	0.1	mg/L	是		闭路循环
					悬浮物	37	17	20	mg/L	是		闭路循环
					阴离子表面活性剂 (LAS)	0.54	0.067	1	mg/L	是		闭路循环
					粪大肠菌群数	35000000	15000	10000	个/L	否	0.5	闭路循环
					氨氮	5	0.756	8	mg/L	是		闭路循环
					总氮	28.8	1.97	20	mg/L	是		闭路循环
					石油类	0.18	<0.04	3	mg/L	是		闭路循环
					动植物油	0.48	<0.04	3	mg/L	是		闭路循环
					温度	28.1	28.2					闭路循环
					温度	18.1	18.2					
					PH值	7.93	7.58	6-9	无量纲	是		
					生化需氧量	55.9	2.3	20	mg/L	是		
					总磷	3.82	0.35	1	mg/L	是		
					化学需氧量	266	26.8	60	mg/L	是		
					色度	8	1	30	倍	是		
					总汞	0.00008	0.00003	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.004	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0015	0.0008	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	126	14	20	mg/L	是		
					阴离子表面活性剂 (LAS)	3.69	0.1	1	mg/L	是		
					粪大肠菌群数	120000000	24000	10000	个/L	否	1.4	
					氨氮	60.6	0.29	8	mg/L	是		
					总氮	64.2	17.2	20	mg/L	是		
					石油类	0.15	<0.04	3	mg/L	是		
					动植物油	0.98	<0.04	3	mg/L	是		

阳泉市	平定县	平定县娘子关污水处理厂	2013-5-13	城镇污水处理厂污染物排放标准	总氮	32.4	26.3	20	mg/L	否	0.3						
					石油类	0.22	<0.04	3	mg/L	是							
					动植物油	0.47	<0.04	3	mg/L	是							
					温度	21.2	21.3										
					总砷	0.001	0.0008	0.1	mg/L	是							
					总铅	<0.01	<0.01	0.1	mg/L	是							
					悬浮物	504	40	20	mg/L	否	1						
					阴离子表面活性剂 (LAS)	1.42	0.06	1	mg/L	是							
					粪大肠菌群数	74000000	37000	10000	个/L	否	2.7						
					氨氮	14.6	11.5	8	mg/L	否	0.4						
					化学需氧量	177	27	60	mg/L	是							
					色度	8	1	30	倍	是							
					总汞	<0.00001	<0.00001	0.001	mg/L	是							
					总镉	<0.001	<0.001	0.01	mg/L	是							
					总铬	<0.004	<0.004	0.1	mg/L	是							
					六价铬	<0.004	<0.004	0.05	mg/L	是							
					PH值	7.4	7.78	6-9	无量纲	是							
					生化需氧量	36	3.5	20	mg/L	是							
					阳泉市	平定县	平定中玮水质净化有限公司	2013-4-10	城镇污水处理厂污染物排放标准	总磷	3.44	2.78	1	mg/L	否	1.8	
										温度	13.2	13.3					
总铅	<0.01	<0.01	0.1	mg/L						是							
悬浮物	362	15	20	mg/L						是							
阴离子表面活性剂 (LAS)	2.42	0.12	1	mg/L						是							
粪大肠菌群数	120000000	7100	10000	个/L						是							
氨氮	50.5	0.745	8	mg/L						是							
总氮	59.8	17.7	20	mg/L						是							
色度	8	1	30	倍						是							
总汞	0.00071	0.00068	0.001	mg/L						是							
总镉	<0.001	<0.001	0.01	mg/L						是							
总铬	<0.004	<0.004	0.1	mg/L						是							
六价铬	<0.004	<0.004	0.05	mg/L						是							
总砷	0.0035	0.0033	0.1	mg/L						是							
PH值	7.73	7.53	6-9	无量纲						是							
生化需氧量	69.7	2.3	20	mg/L						是							
总磷	4.45	0.48	1	mg/L						是							
化学需氧量	414	33	60	mg/L						是							
石油类	0.69	<0.04	3	mg/L						是							
动植物油	2.09	<0.04	3	mg/L						是							
					温度	13	13.2										
					悬浮物	142	40	20	mg/L	否	1						

阳泉市	平定县	阳泉煤业集团有限责任公司升华实业分公司	2013-4-11	城镇污水处理厂污染物排放标准	阴离子表面活性剂 (LAS)	2.61	0.1	1	mg/L	是		
					粪大肠菌群数	87000000	5900	10000	个/L	是		
					氨氮	32.7	0.626	8	mg/L	是		
					总氮	59.1	17.3	20	mg/L	是		
					石油类	0.51	<0.04	3	mg/L	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.004	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0038	0.0037	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					PH值	7.68	7.65	6-9	无量纲	是		
					生化需氧量	59.4	2.4	20	mg/L	是		
					总磷	4.61	0.5	1.5	mg/L	是		
					化学需氧量	244	27.5	60	mg/L	是		
					色度	4	1	30	倍	是		
					动植物油	1.46	<0.04	3	mg/L	是		
阳泉市	孟县	山西孟县正阳污水净化有限公司	2013-4-15	城镇污水处理厂污染物排放标准	温度	13.4	13.3					
					PH值	7.38	7.83	6-9	无量纲	是		
					生化需氧量	87.3	3.2	20	mg/L	是		
					总磷	4.92	0.51	1	mg/L	是		
					化学需氧量	1509	18.9	60	mg/L	是		
					色度	16	1	30	倍	是		
					总汞	0.0001	<0.00001	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.004	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0023	0.002	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	2265	17	20	mg/L	是		
					阴离子表面活性剂 (LAS)	2.21	0.09	1	mg/L	是		
					粪大肠菌群数	160000000	50000	10000	个/L	否	4	
					氨氮	23.5	0.153	8	mg/L	是		
					总氮	58.9	17	20	mg/L	是		
石油类	1.05	<0.04	3	mg/L	是							
动植物油	2.22	<0.04	3	mg/L	是							
					温度	19	19					
					阴离子表面活性剂 (LAS)		0.108	1	mg/L	是		
					粪大肠菌群数		85	10000	个/L	是		
					氨氮	34.7	6.66	8	mg/L	是		

长治市	城 区	长治市供水总公司污水处理厂	2013-4-9	城镇污水处理厂污染物排放标准	总氮		18.3	20	mg/L	是							
					石油类		0.1	3	mg/L	是							
					动植物油		0.29	3	mg/L	是							
					总镉		<0.001	0.01	mg/L	是							
					总铬		<0.004	0.1	mg/L	是							
					六价铬		<0.004	0.05	mg/L	是							
					总砷		<0.0005	0.1	mg/L	是							
					总铅		<0.01	0.1	mg/L	是							
					悬浮物		15	20	mg/L	是							
					PH值		7.42	6-9	无量纲	是							
					生化需氧量		2.4	20	mg/L	是							
					总磷		0.78	1.5	mg/L	是							
					化学需氧量	341	28	60	mg/L	是							
					色度		2	30	倍	是							
					总汞		0.00006	0.001	mg/L	是							
					长治市	郊 区	长治市长北污水处理厂	2013-4-17	城镇污水处理厂污染物排放标准	温度	13.2	13.2					
										石油类		<0.04	1	mg/L	是		
动植物油		<0.04	1	mg/L						是							
总铅		<0.01	0.1	mg/L						是							
悬浮物		10	10	mg/L						是							
阴离子表面活性剂 (LAS)		0.065	0.5	mg/L						是							
粪大肠菌群数		310	1000	个/L						是							
氨氮	26.2	3.04	5	mg/L						是							
总氮		13.4	15	mg/L						是							
色度		2	30	倍						是							
总汞		0.00006	0.001	mg/L						是							
总镉		<0.001	0.01	mg/L						是							
总铬		<0.004	0.1	mg/L						是							
六价铬		<0.004	0.05	mg/L						是							
总砷		0.0008	0.1	mg/L						是							
PH值		7.11	6-9	无量纲						是							
生化需氧量		2.7	10	mg/L						是							
总磷		0.41	0.5	mg/L	是												
化学需氧量	351	30	50	mg/L	是												
					温度	15	15										
					悬浮物		9	10	mg/L	是							
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是							
					粪大肠菌群数		190	1000	个/L	是							
					氨氮	22.2	4.87	5	mg/L	是							
					总氮		12.9	15	mg/L	是							

长治市	郊区	首钢长治钢铁有限公司动力厂生活污水处理站	2013-4-23	城镇污水处理厂污染物排放标准	石油类		0.18	1	mg/L	是		
					总汞		0.00026	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					PH值		7.77	6-9	无量纲	是		
					生化需氧量		4.6	10	mg/L	是		
					总磷		0.43	0.5	mg/L	是		
					化学需氧量	320	26	50	mg/L	是		
					色度		4	30	倍	是		
					动植物油		0.59	1	mg/L	是		
					长治市	长治县	长治县自来水公司污水处理厂	2013-4-16	城镇污水处理厂污染物排放标准	温度	14.8	14.5
PH值		7.69	6-9	无量纲						是		
生化需氧量		8.3	20	mg/L						是		
总磷		0.8	1	mg/L						是		
总氮		16.8	20	mg/L						是		
石油类		0.1	3	mg/L						是		
动植物油		0.33	3	mg/L						是		
总砷		<0.0005	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		8	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.055	1	mg/L						是		
粪大肠菌群数		3500	10000	个/L						是		
氨氮	32.8	6.93	8	mg/L						是		
化学需氧量	302	30	60	mg/L						是		
色度		2	30	倍						是		
总汞		0.00007	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.004	0.1	mg/L	是							
六价铬		<0.004	0.05	mg/L	是							
		山西潞安矿			温度	16.7	15.6					
					氨氮	34.7	7	8	mg/L	是		
					总氮		18.4	20	mg/L	是		
					石油类		<0.04	3	mg/L	是		
					动植物油		<0.04	3	mg/L	是		
					PH值		7.76	6-9	无量纲	是		
					生化需氧量		8	20	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		

长治市	襄垣县	山西晋光矿业(集团)有限责任公司后勤中心	2013-4-24	城镇污水处理厂污染物排放标准	总砷		<0.0005	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		8	20	mg/L	是		
					阴离子表面活性剂(LAS)		0.053	1	mg/L	是		
					粪大肠菌群数		920	10000	个/L	是		
					总磷		0.78	1	mg/L	是		
					化学需氧量	314	26	60	mg/L	是		
					色度		4	30	倍	是		
					总汞		0.00008	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					长治市	襄垣县	山西襄矿能源投资管理集团有限公司	2013-5-6	城镇污水处理厂污染物排放标准	温度	18	18
阴离子表面活性剂(LAS)		0.054	0.5	mg/L						是		
粪大肠菌群数		770	1000	个/L						是		
氨氮	3.17	0.551	5	mg/L						是		
总氮	3.75	0.613	15	mg/L						是		
石油类		<0.04	1	mg/L						是		
动植物油		<0.04	1	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.004	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		<0.0005	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物	216	9.4	10	mg/L						是		
PH值	8.37	7.85	6-9	无量纲						是		
生化需氧量	53.3	8.6	10	mg/L						是		
总磷	2.62	0.497	0.5	mg/L						是		
化学需氧量	226	23.1	50	mg/L						是		
色度		4	30	倍						是		
总汞		<0.00005	0.001	mg/L	是							
长治市	襄垣县	襄垣县永清有限责任公司	2013-4-2	城镇污水处理厂污染物排放标准	温度	16.2	16.2					
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		16	20	mg/L	是		
					阴离子表面活性剂(LAS)		0.091	1	mg/L	是		
					生化需氧量		6.7	20	mg/L	是		
					总磷		0.4	1	mg/L	是		
					化学需氧量	285	36	60	mg/L	是		

					悬浮物		8	10	mg/L	是		
					PH值		7.6	6-9	无量纲	是		
					生化需氧量		6	10	mg/L	是		
					总磷		0.49	0.5	mg/L	是		
					化学需氧量	341	35	50	mg/L	是		
					色度		2	30	倍	是		
					总汞		0.00006	0.001	mg/L	是		
长治市	黎城县	黎城县污水处理中心	2013-4-12	城镇污水处理厂污染物排放标准	温度	13.6	13.6					
					PH值		7.66	6-9	无量纲	是		
					生化需氧量		9.8	20	mg/L	是		
					总磷		0.66	1.5	mg/L	是		
					化学需氧量	307	28	60	mg/L	是		
					色度		2	30	倍	是		
					悬浮物		15	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.119	1	mg/L	是		
					粪大肠菌群数		5200	10000	个/L	是		
					氨氮	37.3	7.7	8	mg/L	是		
					总氮		18.1	20	mg/L	是		
					石油类		0.13	3	mg/L	是		
					总汞		0.00006	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					动植物油		0.41	3	mg/L	是		
					长治市	壶关县	壶关县洁城污水处理有限公司	2013-4-12	城镇污水处理厂污染物排放标准	温度	13.6	13.8
动植物油		0.68	3	mg/L						是		
PH值		7.63	6-9	无量纲						是		
生化需氧量		7.5	20	mg/L						是		
总磷		0.88	1	mg/L						是		
化学需氧量	335	29	60	mg/L						是		
色度		4	30	倍						是		
悬浮物		13	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.102	1	mg/L						是		
粪大肠菌群数		2500	10000	个/L						是		
氨氮	25.2	4.52	8	mg/L						是		
总氮		18.5	20	mg/L						是		
石油类		0.22	3	mg/L						是		
总汞		<0.00005	0.001	mg/L	是							

					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
长治市	长子县	长子县给排水中心	2013-4-10	城镇污水处理厂污染物排放标准	温度	18.3	18.3					
					石油类		<0.04	1	mg/L	是		
					动植物油		<0.04	1	mg/L	是		
					PH值		7.7	6-9	无量纲	是		
					生化需氧量		2.6	10	mg/L	是		
					总磷		0.4	0.5	mg/L	是		
					化学需氧量	315	36	50	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		6	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.079	0.5	mg/L	是		
					粪大肠菌群数		360	1000	个/L	是		
					氨氮	22.2	2.02	5	mg/L	是		
					总氮		13.4	15	mg/L	是		
					色度		2	30	倍	是		
					总汞		<0.00005	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					长治市	武乡县	武乡西电净水有限公司	2013-4-10	城镇污水处理厂污染物排放标准	温度	12.9	12.8
PH值		7.73	6-9	无量纲						是		
生化需氧量		5.6	10	mg/L						是		
总磷		0.49	0.5	mg/L						是		
化学需氧量	324	27	50	mg/L						是		
色度		2	30	倍						是		
总汞		0.0002	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.004	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		<0.0005	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		8	10	mg/L						是		
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是		
粪大肠菌群数		410	1000	个/L	是							
氨氮	24.8	4.01	5	mg/L	是							

					总氮		13.5	15	mg/L	是		
					石油类		0.06	1	mg/L	是		
					动植物油		0.18	1	mg/L	是		
长治市	沁县	沁县自来水公司污水处理厂	2013-4-2	城镇污水处理厂污染物排放标准	温度	14	14.5					
					石油类		0.07	3	mg/L	是		
					动植物油		0.24	3	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		8	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.053	1	mg/L	是		
					粪大肠菌群数		4400	10000	个/L	是		
					氨氮	37.3	6.48	8	mg/L	是		
					总氮		18.8	20	mg/L	是		
					色度		2	30	倍	是		
					总汞		<0.00005	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.004	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		<0.0005	0.1	mg/L	是		
					PH值		7.92	6-9	无量纲	是		
					生化需氧量		6.4	20	mg/L	是		
					总磷		0.51	1	mg/L	是		
					化学需氧量	309	27	60	mg/L	是		
					长治市	沁源县	沁源县净水有限公司	2013-4-18	城镇污水处理厂污染物排放标准	温度	16	15.7
PH值		7.63	6-9	无量纲						是		
生化需氧量		8.6	10	mg/L						是		
总磷		0.38	0.5	mg/L						是		
化学需氧量	314	40	50	mg/L						是		
色度		2	30	倍						是		
总汞		0.00007	0.001	mg/L						是		
阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L						是		
粪大肠菌群数		690	1000	个/L						是		
氨氮	30	2.02	5	mg/L						是		
总氮		13.2	15	mg/L						是		
石油类		0.1	1	mg/L						是		
动植物油		0.32	1	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.004	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		<0.0005	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L	是							

长治市	潞城市	潞城市城市污水处理厂	2013-4-12	城镇污水处理厂污染物排放标准	悬浮物		10	10	mg/L	是			
					温度	12.5	12.5						
					总砷		<0.0005	0.1	mg/L	是			
					总铅		<0.01	0.1	mg/L	是			
					悬浮物		13	20	mg/L	是			
					阴离子表面活性剂 (LAS)		0.152	1	mg/L	是			
					粪大肠菌群数		1900	10000	个/L	是			
					氨氮	25.4	5.1	8	mg/L	是			
					化学需氧量	304	23	60	mg/L	是			
					色度		4	30	倍	是			
					总汞		0.00006	0.001	mg/L	是			
					总镉		<0.001	0.01	mg/L	是			
					总铬		<0.004	0.1	mg/L	是			
					六价铬		<0.004	0.05	mg/L	是			
					PH值		7.81	6-9	无量纲	是			
					生化需氧量		3.4	20	mg/L	是			
					总磷		0.89	1.5	mg/L	是			
					总氮		18	20	mg/L	是			
					石油类		<0.04	3	mg/L	是			
动植物油		<0.04	3	mg/L	是								
晋城市	城 区	晋城蓝焰煤业股份有限公司凤凰山矿生活污水处理厂	2013-5-13	城镇污水处理厂污染物排放标准	温度	26	23.1						
					PH值		7.76	6-9	无量纲	是			
					生化需氧量		5.4	10	mg/L	是			
					总磷		0.405	0.5	mg/L	是			
					化学需氧量	135	16	50	mg/L	是			
					色度		0	30	倍	是			
					总汞		<0.00001	0.001	mg/L	是			
					烷基汞		<0.00001	0	mg/L	是			
					总镉		<0.0005	0.01	mg/L	是			
					总铬		<0.004	0.1	mg/L	是			
					六价铬		<0.004	0.05	mg/L	是			
					总砷		<0.007	0.1	mg/L	是			
					总铅		<0.004	0.1	mg/L	是			
					悬浮物		10	10	mg/L	是			
					阴离子表面活性剂 (LAS)		0.055	0.5	mg/L	是			
					粪大肠菌群数		800	1000	个/L	是			
					氨氮	19.2	4.34	5	mg/L	是			
					总氮		6.09	15	mg/L	是			
					石油类		0.04	1	mg/L	是			
动植物油		<0.04	1	mg/L	是								

晋城市	城 区	晋城市镇源污水处理厂	2013-4-13	城镇污水处理厂污染物排放标准	温度	23.8	22.9					
					PH值	7.43	7.4	6-9	无量纲	是		
					生化需氧量	162	6.8	10	mg/L	是		
					总磷	4.13	0.395	1	mg/L	是		
					化学需氧量	392	21	50	mg/L	是		
					色度	5	0	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.031	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	130	9	10	mg/L	是		
					阴离子表面活性剂 (LAS)	0.152	0.096	0.5	mg/L	是		
					粪大肠菌群数	9200000	783	1000	mg/L	是		
					氨氮	46.3	2.89	5	mg/L	是		
					总氮	84.2	4.1	15	mg/L	是		
					石油类	0.76	0.04	1	mg/L	是		
动植物油	0.99	0.05	1	mg/L	是							
晋城市	城 区	晋煤集团机关物业公司污水处理厂	2013-4-18	城镇污水处理厂污染物排放标准	温度	24	22.6					
					PH值	7.83	7.79	6-9	无量纲	是		
					生化需氧量	82	4.3	20	mg/L	是		
					总磷	2.77	0.373	1	mg/L	是		
					化学需氧量	210	13	60	mg/L	是		
					色度	5	0	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.027	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	232	9	20	mg/L	是		
					阴离子表面活性剂 (LAS)	0.092	0.08	1	mg/L	是		
					粪大肠菌群数	16000000	735	10000	个/L	是		
					氨氮	23.8	0.297	8	mg/L	是		
					总氮	41.3	0.42	20	mg/L	是		
					石油类	0.77	0.005	3	mg/L	是		
动植物油	0.54	0.006	3	mg/L	是							

晋城市	沁水县	沁水中利久泰环保科技有限公司	2013-5-8	城镇污水处理厂污染物排放标准	温度	19	19					
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	255	10	20	mg/L	是		
					阴离子表面活性剂 (LAS)	0.08	0.054	1	mg/L	是		
					粪大肠菌群数	9200000	7000	10000	个/L	是		
					氨氮	24.4	2.46	8	mg/L	是		
					总氮	41.5	3.5	20	mg/L	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.022	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					石油类	0.75	<0.04	3	mg/L	是		
					动植物油	0.78	0.05	3	mg/L	是		
					PH值	7.98	7.75	6-9	无量纲	是		
					生化需氧量	100	5.5	20	mg/L	是		
					总磷	2.73	0.402	1	mg/L	是		
					化学需氧量	253	16	60	mg/L	是		
					色度	5	0	30	倍	是		
晋城市	阳城县	阳城县安阳污水处理有限公司	2013-5-8	城镇污水处理厂污染物排放标准	温度	25.1	23.3					
					PH值	7.86	7.74	6-9	无量纲	是		
					生化需氧量	156	9	20	mg/L	是		
					总磷	1.82	0.377	1	mg/L	是		
					化学需氧量	375	26	60	mg/L	是		
					色度	5	0	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.027	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	220	10	20	mg/L	是		
					阴离子表面活性剂 (LAS)	0.104	0.064	1	mg/L	是		
					粪大肠菌群数	5400000	983	10000	个/L	是		
					氨氮	31.2	3.57	8	mg/L	是		
总氮	59.5	5.03	20	mg/L	是							
石油类	0.81	<0.04	3	mg/L	是							
动植物油	0.74	<0.04	3	mg/L	是							

晋城市	陵川县	陵川县洁美污水处理有限公司	2013-5-14	城镇污水处理厂污染物排放标准	温度	25.7	23.4					
					PH值	7.51	7.42	6-9	无量纲	是		
					生化需氧量	188	7.4	10	mg/L	是		
					总磷	2.09	0.282	0.5	mg/L	是		
					化学需氧量	375	22	50	mg/L	是		
					色度	5	0	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.029	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	215	9	10	mg/L	是		
					阴离子表面活性剂 (LAS)	0.116	0.075	0.5	mg/L	是		
					粪大肠菌群数	9200000	800	1000	个/L	是		
					氨氮	59.8	4.5	5	mg/L	是		
					总氮	91.4	7.47	15	mg/L	是		
					石油类	1.47	0.05	1	mg/L	是		
动植物油	1.74	0.05	1	mg/L	是							
晋城市	泽州县	晋城蓝焰煤业股份有限公司成庄矿生活污水处理厂	2013-5-10	污水综合排放标准	PH值		7.92	6-9	无量纲	是		
					生化需氧量		4.4	30	mg/l	是		
					化学需氧量	124	15	150	mg/l	是		
					悬浮物		40	150	mg/l	是		
					阴离子表面活性剂 (LAS)		0.074	10	mg/l	是		
					氨氮	20	4.66	25	mg/L	是		
					硫化物		<0.005	1	mg/l	是		
石油类		0.08	10	mg/l	是							
晋城市	泽州县	山西兰花工业污水处理有限公司	2013-5-9	城镇污水处理厂污染物排放标准	温度	24.6	21.5					
					PH值	7.89	7.54	6-9	无量纲	是		
					生化需氧量	78.7	5.9	30	mg/L	是		
					总磷	4.53	0.263	3	mg/L	是		
					化学需氧量	204	17	100	mg/L	是		
					色度	10	0	40	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.021	<0.004	0.1	mg/L	是		
六价铬	<0.004	<0.004	0.05	mg/L	是							
总砷	<0.007	<0.007	0.1	mg/L	是							

					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	284	25	30	mg/L	是		
					阴离子表面活性剂 (LAS)	0.096	0.063	2	mg/L	是		
					粪大肠菌群数	5400000	2950	10000	个/L	是		
					氨氮	35.3	7.77	25	mg/L	是		
					总氮	63.5	10.9		mg/L			
					石油类	0.14	0.05	5	mg/L	是		
					动植物油	0.19	0.06	5	mg/L	是		
晋城市	泽州县	山西天泽煤化工集团股份公司污水处理站	2013-4-11	合成氨工业水污染物排放标准	PH值		7.19	6-9	无量纲	是		
					化学需氧量	318	28	150	mg/L	是		
					挥发酚		<0.01	0.1	mg/L	是		
					悬浮物		44	100	mg/L	是		
					氨氮	75.5	12.3	70	mg/L	是		
					氰化物 (总氰化合物)		0.046	1	mg/L	是		
					硫化物		<0.005	0.5	mg/L	是		
					石油类		0.06	5	mg/L	是		
晋城市	高平市	山西高平天阳污水净化有限公司	2013-5-15	城镇污水处理厂污染物排放标准	温度	23.9	21.4					
					PH值	7.9	7.83	6-9	无量纲	是		
					生化需氧量	228	9.7	20	mg/L	是		
					总磷	2.17	0.406	1	mg/L	是		
					化学需氧量	524	28	60	mg/L	是		
					色度	5	0	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					烷基汞	<0.00001	<0.00001	0	mg/L	是		
					总镉	<0.0005	<0.0005	0.01	mg/L	是		
					总铬	0.027	<0.004	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	<0.003	<0.003	0.1	mg/L	是		
					悬浮物	200	9	20	mg/L	是		
					阴离子表面活性剂 (LAS)	0.189	0.094	1	mg/L	是		
					粪大肠菌群数	9200000	8100	10000	个/L	是		
					氨氮	27.4	2.12	8	mg/L	是		
					总氮	47.5	3	20	mg/L	是		
					石油类	1.13	<0.04	3	mg/L	是		
					动植物油	1.34	<0.04	3	mg/L	是		
					温度	12.8	13.2					
					PH值	7.46	7.27	6-9	无量纲	是		
					生化需氧量	180	17.7	20	mg/L	是		
					总磷	5.95	1.03	1.5	mg/L	是		

朔州市	朔城区	朔州市污水处理厂	2013-4-23	城镇污水处理厂 污染物排放标准	化学需氧量	396	46	60	mg/L	是		
					色度	63	14	30	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					总镉	<0.01	<0.01	0.01	mg/L	是		
					总铬	0.035	0.006	0.1	mg/L	是		
					六价铬	0.02	<0.004	0.05	mg/L	是		
					总砷	<0.0005	<0.0005	0.1	mg/L	是		
					总铅	<0.08	<0.08	0.1	mg/L	是		
					悬浮物	312	18	20	mg/L	是		
					阴离子表面活性剂 (LAS)	3.41	0.201	1	mg/L	是		
					粪大肠菌群数	200500	6583	10000	个/L	是		
					氨氮	48	10.3	8	mg/L	否	0.3	
					总氮	77.4	24.3	20	mg/L	否	0.2	
					石油类	4.44	0.62	3	mg/L	是		
					动植物油	4.52	0.67	3	mg/L	是		
					朔州市	平鲁区	平鲁区污水处理厂	2013-5-23	城镇污水处理厂 污染物排放标准	温度	17.8	17.2
PH值	7.69	7.36	6-9	无量纲						是		
生化需氧量	155	16	20	mg/L						是		
总磷	4.83	0.44	1	mg/L						是		
化学需氧量	446	42	60	mg/L						是		
色度	65	13	30	倍						是		
总汞	0.00013	0.00007	0.001	mg/L						是		
总镉	<0.01	<0.01	0.01	mg/L						是		
总铬	0.118	0.022	0.1	mg/L						是		
六价铬	0.031	0.006	0.05	mg/L						是		
总砷	<0.0005	<0.0005	0.1	mg/L						是		
总铅	<0.08	<0.08	0.1	mg/L						是		
悬浮物	378	18	20	mg/L						是		
阴离子表面活性剂 (LAS)	5.55	0.301	1	mg/L						是		
粪大肠菌群数	58833	5883	10000	个/L						是		
氨氮	43.3	4.72	8	mg/L						是		
总氮	58.2	17.9	20	mg/L	是							
石油类	0.42	0.03	3	mg/L	是							
动植物油	0.46	0.04	3	mg/L	是							
					温度	16.6	16.9					
					PH值	7.67	7.25	6-9	无量纲	是		
					生化需氧量	115	11.4	20	mg/L	是		
					总磷	5.51	0.377	1.5	mg/L	是		
					化学需氧量	442	45	60	mg/L	是		
					色度	59	9	30	倍	是		

朔州市	山阴县	山阴县污水处理厂	2013-5-27	城镇污水处理厂 污染物排放标准	总汞	<0.00001	<0.00001	0.001	mg/L	是		
					总镉	<0.01	<0.01	0.01	mg/L	是		
					总铬	0.081	0.013	0.1	mg/L	是		
					六价铬	0.054	0.005	0.05	mg/L	是		
					总砷	<0.0005	<0.0005	0.1	mg/L	是		
					总铅	<0.08	<0.08	0.1	mg/L	是		
					悬浮物	313	17	20	mg/L	是		
					阴离子表面活性剂 (LAS)	3.47	0.202	1	mg/L	是		
					粪大肠菌群数	86000	7066	10000	个/L	是		
					氨氮	41.8	6.03	8	mg/L	是		
					总氮	53	16.3	20	mg/L	是		
					石油类	0.33	0.07	3	mg/L	是		
					动植物油	0.35	0.07	3	mg/L	是		
					朔州市	应县	应县县城污水处理厂	2013-5-31	城镇污水处理厂 污染物排放标准	温度	16.3	17.3
PH值	7.6	7.3	6-9	无量纲						是		
生化需氧量	165	16.9	20	mg/L						是		
总磷	4.94	0.468	1.5	mg/L						是		
化学需氧量	434	43	60	mg/L						是		
色度	65	11	30	倍						是		
总汞	<0.00001	<0.00001	0.001	mg/L						是		
总镉	<0.01	<0.01	0.01	mg/L						是		
总铬	0.158	0.024	0.1	mg/L						是		
六价铬	0.079	0.01	0.05	mg/L						是		
总砷	<0.0005	<0.0005	0.1	mg/L						是		
总铅	<0.08	<0.08	0.1	mg/L						是		
悬浮物	358	18	20	mg/L						是		
阴离子表面活性剂 (LAS)	3.25	0.301	1	mg/L						是		
粪大肠菌群数	67333	4100	10000	个/L						是		
氨氮	43.7	6.95	8	mg/L						是		
总氮	55.3	17.4	20	mg/L						是		
石油类	1.74	0.07	3	mg/L						是		
动植物油	1.92	0.09	3	mg/L						是		
										温度	15.5	16.6
					悬浮物	202	6	10	mg/L	是		
					阴离子表面活性剂 (LAS)	3.76	0.15	0.5	mg/L	是		
					粪大肠菌群数	36833	602	1000	个/L	是		
					氨氮	38.7	4.25	5	mg/L	是		
					总氮	60.5	13.3	15	mg/L	是		
					石油类	0.12	0.04	1	mg/L	是		
总汞	<0.00001	<0.00001	0.001	mg/L	是							

朔州市	右玉县	右玉县清环猗顿城市污水处理厂	2013-5-29	城镇污水处理厂污染物排放标准	总镉	<0.01	<0.01	0.01	mg/L	是		
					总铬	0.081	0.012	0.1	mg/L	是		
					六价铬	0.054	0.005	0.05	mg/L	是		
					总砷	<0.0005	<0.0005	0.1	mg/L	是		
					总铅	<0.08	<0.08	0.1	mg/L	是		
					PH值	7.75	7.24	6-9	无量纲	是		
					生化需氧量	75.2	8.6	10	mg/L	是		
					总磷	4.96	0.423	0.5	mg/L	是		
					化学需氧量	323	35	50	mg/L	是		
					色度	70	13	30	倍	是		
					动植物油	0.14	0.04	1	mg/L	是		
朔州市	怀仁县	怀仁县污水处理厂工程建设项目部	2013-5-27	城镇污水处理厂污染物排放标准	温度	16.8	17.6					
					PH值	7.7	7.38	6-9	无量纲	是		
					生化需氧量	158	18	30	mg/L	是		
					总磷	5.51	0.482	3	mg/L	是		
					化学需氧量	403	46	100	mg/L	是		
					色度	62	9	40	倍	是		
					总汞	<0.00001	<0.00001	0.001	mg/L	是		
					总镉	<0.01	<0.01	0.01	mg/L	是		
					总铬	0.09	0.014	0.1	mg/L	是		
					六价铬	0.066	0.008	0.05	mg/L	是		
					总砷	<0.0005	<0.0005	0.1	mg/L	是		
					悬浮物	327	15	30	mg/L	是		
					阴离子表面活性剂 (LAS)	3.85	0.188	2	mg/L	是		
					粪大肠菌群数	58833	5517	10000	个/L	是		
					氨氮	52.9	12.5	25	mg/L	是		
					总氮	67	24.5		mg/L			
					石油类	0.39	0.07	5	mg/L	是		
动植物油	0.44	0.08	5	mg/L	是							
晋中市	榆次区	山西国际电力集团正阳污水净化有限公司(二	2013-4-11	城镇污水处理厂污染物排放标准	温度	12.8	13.7					
					PH值	8.16	7.61	6-9	无量纲	是		
					生化需氧量	101	2.1	10	mg/L	是		
					总磷	4.19	0.25	0.5	mg/L	是		
					化学需氧量	275	14	50	mg/L	是		
					色度	100	8	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
总砷		0.001	0.1	mg/L	是							

		厂)			总铅		<0.0002	0.1	mg/L	是		
					悬浮物	111	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)		<0.05	0.5	mg/L	是		
					粪大肠菌群数		140	1000	个/L	是		
					氨氮	52	4.54	5	mg/L	是		
					总氮	58.8	9.72	15	mg/L	是		
					石油类	0.54	0.04	1	mg/L	是		
					动植物油		0.06	1	mg/L	是		
晋中市	榆次区	山西国际电力集团正阳污水净化有限公司(一厂)	2013-4-11	城镇污水处理厂污染物排放标准	温度	15.2	13.6					
					PH值	7.83	7.62	6-9	无量纲	是		
					生化需氧量	160	3.2	20	mg/L	是		
					总磷	7.12	0.07	1.5	mg/L	是		
					化学需氧量	470	19	60	mg/L	是		
					色度	100	10	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0006	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	148	18	20	mg/L	是		
					阴离子表面活性剂 (LAS)		<0.05	1	mg/L	是		
					粪大肠菌群数		<3	10000	个/L	是		
					氨氮	54.1	0.664	8	mg/L	是		
					总氮	75.2	14	20	mg/L	是		
					石油类	1.24	<0.01	3	mg/L	是		
					动植物油		0.04	3	mg/L	是		
晋中市	榆社县	榆社县污水处理中心	2013-4-16	城镇污水处理厂污染物排放标准	温度	14.5	16					
					总砷		0.0029	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	86	19	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.36	1	mg/L	是		
					粪大肠菌群数		9400	10000	个/L	是		
					氨氮	45.6	4.18	8	mg/L	是		
					化学需氧量	406	41	60	mg/L	是		
					色度	200	20	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
总铬		<0.03	0.1	mg/L	是							
六价铬		<0.004	0.05	mg/L	是							

					氨氮	19.9	6.55	8	mg/L	是		
					总氮	35.1	19.6	20	mg/L	是		
					石油类	0.24	0.11	3	mg/L	是		
					动植物油		0.16	3	mg/L	是		
晋中市	昔阳县	昔阳县污水处理厂筹建处	2013-4-16	城镇污水处理厂污染物排放标准	温度	14.9	14.4					
					PH值	7.45	6.97	6-9	无量纲	是		
					生化需氧量	166	6.7	20	mg/L	是		
					总磷	5.86	0.75	1	mg/L	是		
					化学需氧量	475	24	60	mg/L	是		
					色度	100	8	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0011	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	308	19	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.1	1	mg/L	是		
					粪大肠菌群数		7700	10000	个/L	是		
					氨氮	39.3	0.591	8	mg/L	是		
					总氮	53.8	13.5	20	mg/L	是		
					石油类	2.32	0.02	3	mg/L	是		
					动植物油		0.06	3	mg/L	是		
					晋中市	寿阳县	寿阳县污水处理厂有限公司	2013-4-17	城镇污水处理厂污染物排放标准	温度	11.2	12.7
PH值	7.39	7.87	6-9	无量纲						是		
生化需氧量	171	15.8	20	mg/L						是		
总磷	3.54	0.9	1	mg/L						是		
化学需氧量	441	48	60	mg/L						是		
色度	100	10	30	倍						是		
总汞		<0.00008	0.001	mg/L						是		
总镉		<0.00002	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		0.0024	0.1	mg/L						是		
总铅		<0.0002	0.1	mg/L						是		
悬浮物	128	16	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.1	1	mg/L						是		
粪大肠菌群数		8800	10000	个/L						是		
氨氮	23.7	7.5	8	mg/L						是		
总氮	34.7	14.4	20	mg/L	是							

晋中市	太谷县	太谷县圣源环保污水处理有限公司	2013-4-15	城镇污水处理厂污染物排放标准	石油类	0.58	0.03	3	mg/L	是		
					动植物油		0.2	3	mg/L	是		
					温度	15.2	16.2					
					阴离子表面活性剂 (LAS)		0.11	1	mg/L	是		
					粪大肠菌群数		9900	10000	个/L	是		
					氨氮	46.7	7.32	8	mg/L	是		
					总氮	66.2	17	20	mg/L	是		
					石油类	1.42	0.02	3	mg/L	是		
					动植物油		0.2	3	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0017	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	172	19	20	mg/L	是		
					PH值	7.39	7.71	6-9	无量纲	是		
					生化需氧量	161	14.1	20	mg/L	是		
					总磷	12.8	0.2	1	mg/L	是		
					化学需氧量	482	45	60	mg/L	是		
					色度	100	10	30	倍	是		
总汞		<0.00008	0.001	mg/L	是							
晋中市	祁 县	祁县鸿宇市政污水处理有限公司	2013-4-11	城镇污水处理厂污染物排放标准	温度	14.8	15.1					
					PH值	7.51	7.56	6-9	无量纲	是		
					生化需氧量	130	8	20	mg/L	是		
					总磷	3.81	0.49	1	mg/L	是		
					化学需氧量	299	38	60	mg/L	是		
					色度	50	20	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0019	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	80	20	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.1	1	mg/L	是		
					粪大肠菌群数		9300	10000	个/L	是		
					氨氮	52.9	6.9	8	mg/L	是		
					总氮	62.4	15.7	20	mg/L	是		
					石油类	0.79	0.26	3	mg/L	是		
动植物油		0.2	3	mg/L	是							

晋中市	平遥县	平遥县瑞思污水处理有限公司	2013-4-11	城镇污水处理厂污染物排放标准	温度	13.6	14.6					
					PH值	7.64	7.51	6-9	无量纲	是		
					生化需氧量	136	6	20	mg/L	是		
					总磷	7.4	0.19	1	mg/L	是		
					化学需氧量	398	34	60	mg/L	是		
					色度	100	10	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0012	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	118	13	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.11	1	mg/L	是		
					粪大肠菌群数		9400	10000	个/L	是		
					氨氮	40.7	7.24	8	mg/L	是		
					总氮	54.2	17.9	20	mg/L	是		
石油类	1.45	0.04	3	mg/L	是							
动植物油		0.08	3	mg/L	是							
晋中市	灵石县	灵石县保净污水处理有限公司	2013-4-10	城镇污水处理厂污染物排放标准	温度	12.4	12.1					
					PH值	7.56	7.5	6-9	无量纲	是		
					生化需氧量	113	1.9	10	mg/L	是		
					总磷	2.45	0.47	0.5	mg/L	是		
					化学需氧量	316	12	50	mg/L	是		
					色度	100	10	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0016	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	110	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.1	0.5	mg/L	是		
					粪大肠菌群数		370	1000	个/L	是		
					氨氮	38.2	0.352	5	mg/L	是		
					总氮	43.5	4.22	15	mg/L	是		
石油类	0.26	0.02	1	mg/L	是							
动植物油		0.07	1	mg/L	是							
					温度	15	14					
					PH值	7.84	7.53	6-9	无量纲	是		

晋中市	介休市	介休市帅达污水处理有限公司	2013-4-10	城镇污水处理厂污染物排放标准	生化需氧量	183	1.8	10	mg/L	是		
					总磷	5.35	0.07	0.5	mg/L	是		
					化学需氧量	382	23	50	mg/L	是		
					色度	100	20	30	倍	是		
					总汞		<0.00008	0.001	mg/L	是		
					总镉		<0.00002	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.008	0.05	mg/L	是		
					总砷		0.001	0.1	mg/L	是		
					总铅		<0.0002	0.1	mg/L	是		
					悬浮物	115	5	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.12	0.5	mg/L	是		
					粪大肠菌群数		940	1000	个/L	是		
					氨氮	53.4	0.413	5	mg/L	是		
					总氮	62.7	7.6	15	mg/L	是		
					石油类	1.36	<0.01	1	mg/L	是		
					动植物油		0.06	1	mg/L	是		
运城市	盐湖区	运城市城东污水处理中心	2013-5-22	城镇污水处理厂污染物排放标准	温度		20					
					PH值		7.41	6-9	无量纲	是		
					生化需氧量	68.3	7.9	10	mg/L	是		
					总磷		0.4	0.5	mg/L	是		
					化学需氧量	334	34.9	50	mg/L	是		
					色度		8	30	倍	是		
					总汞		0.00018	0.001	mg/L	是		
					阴离子表面活性剂 (LAS)	2.02	0.252	0.5	mg/L	是		
					粪大肠菌群数		24000	1000	个/L	否	23	
					氨氮	28.5	2.07	5	mg/L	是		
					总氮	52.1	11.1	15	mg/L	是		
					石油类		0.11	1	mg/L	是		
					动植物油		0.14	1	mg/L	是		
					总镉		0.001	0.01	mg/L	是		
					总铬		0.03	0.1	mg/L	是		
					六价铬		0.013	0.05	mg/L	是		
					总砷		0.0055	0.1	mg/L	是		
总铅		0.01	0.1	mg/L	是							
悬浮物		9	10	mg/L	是							
					温度		16.5					
					PH值		7.65	6-9	无量纲	是		
					生化需氧量	53.6	7.67	30	mg/L	是		
					总磷		0.13	3	mg/L	是		

运城市	盐湖区	运城市富斯特污水处理有限公司	2013-5-23	城镇污水处理厂污染物排放标准	化学需氧量	410	34.7	100	mg/L	是		
					色度		10	40	倍	是		
					总汞		0.00013	0.001	mg/L	是		
					总镉		0.001	0.01	mg/L	是		
					总铬		0.03	0.1	mg/L	是		
					六价铬		0.007	0.05	mg/L	是		
					总砷		0.0083	0.1	mg/L	是		
					总铅		0.01	0.1	mg/L	是		
					悬浮物		29	30	mg/L	是		
					阴离子表面活性剂 (LAS)	2.93	0.222	2	mg/L	是		
					粪大肠菌群数		24000	10000	个/L	否	1.4	
					氨氮	30.5	5.38	25	mg/L	是		
					总氮	50.4	12		mg/L			
					石油类		0.28	5	mg/L	是		
					动植物油		0.4	5	mg/L	是		
					运城市	临猗县	临猗县城市污水处理有限公司	2013-5-26	城镇污水处理厂污染物排放标准	温度		15.8
PH值		7.26	6-9	无量纲						是		
生化需氧量		8.8	20	mg/L						是		
总磷		0.76	1	mg/L						是		
化学需氧量	225	36	60	mg/L						是		
色度		20	30	mg/L						是		
总汞		0.0008	0.001	mg/L						是		
总镉		<0.003	0.01	mg/L						是		
总铬		0.04	0.1	mg/L						是		
六价铬		0.026	0.05	mg/L						是		
总砷		0.045	0.1	mg/L						是		
总铅		<0.05	0.1	mg/L						是		
悬浮物		15.4	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.25	1	mg/L						是		
粪大肠菌群数		2700	10000	个/L						是		
氨氮	160	4.2	8	mg/L						是		
总氮		7.6	20	mg/L	是							
石油类		0.26	3	mg/L	是							
动植物油		0.082	3	mg/L	是							
					温度		22					
					PH值		6.9	6-9	无量纲	是		
					生化需氧量		18	20	mg/L	是		
					总磷		0.248	1	mg/L	是		
					化学需氧量	502	34.1	60	mg/L	是		
色度		4	30	倍	是							

运城市	万荣县	万荣县荣碧污水处理厂	2013-6-3	城镇污水处理厂污染物排放标准	总汞		<0.0001	0.001	mg/L	是		
					总镉		<0.003	0.01	mg/L	是		
					总铬		0.025	0.1	mg/L	是		
					六价铬		0.011	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.05	0.1	mg/L	是		
					悬浮物		16	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.745	1	mg/L	是		
					粪大肠菌群数		7000	10000	个/L	是		
					氨氮	43	4.31	8	mg/L	是		
					总氮		12.4	20	mg/L	是		
					石油类		0.36	3	mg/L	是		
					动植物油		0.745	3	mg/L	是		
					运城市	闻喜县	闻喜县源清污水处理有限公司	2013-5-14	城镇污水处理厂污染物排放标准	温度		15.5
PH值		7.64	6-9	无量纲						是		
生化需氧量		6.3	10	mg/L						是		
总磷		0.484	0.5	mg/L						是		
化学需氧量	146	35.5	50	mg/L						是		
色度		20	30	倍						是		
总汞		<0.00001	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		0.031	0.1	mg/L						是		
六价铬		0.028	0.05	mg/L						是		
总砷		0.001	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		9	10	mg/L						是		
阴离子表面活性剂 (LAS)		0.103	0.5	mg/L						是		
粪大肠菌群数		460	1000	个/L						是		
氨氮	32.5	2.64	5	mg/L						是		
总氮		12.8	15	mg/L						是		
石油类		<0.04	1	mg/L						是		
动植物油		<0.04	1	mg/L	是							
					温度		16.5					
					PH值		7.66	6-9	无量纲	是		
					生化需氧量		8.7	10	mg/L	是		
					总磷		0.05	0.5	mg/L	是		
					化学需氧量	268	19.02	50	mg/L	是		
					色度		8	30	倍	是		
					总汞		<0.00001	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		

运城市	稷山县	稷山县源清污水处理有限公司	2013-5-13	城镇污水处理厂污染物排放标准	总铬		<0.03	0.1	mg/L	是		
					六价铬		<0.004	0.05	mg/L	是		
					总砷		0.0037	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		8	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.101	0.5	mg/L	是		
					粪大肠菌群数		460	1000	个/L	是		
					氨氮	82.5	0.109	5	mg/L	是		
					总氮		1.09	15	mg/L	是		
					石油类		<0.04	1	mg/L	是		
					动植物油		<0.04	1	mg/L	是		
运城市	新绛县	新绛县城区污水处理厂	2013-4-22	城镇污水处理厂污染物排放标准	温度		9					
					PH值	8.04	7.3	6-9	无量纲	是		
					生化需氧量	64.3	17.8	20	mg/L	是		
					总磷	5.58	0.96	1	mg/L	是		
					化学需氧量	261	46.7	60	mg/L	是		
					色度	56	17	30	倍	是		
					总汞	0.012	<0.001	0.001	mg/L	是		
					总镉	0.09	<0.001	0.01	mg/L	是		
					总铬	0.17	<0.03	0.1	mg/L	是		
					六价铬	0.13	0.035	0.05	mg/L	是		
					总砷	0.04	0.018	0.1	mg/L	是		
					总铅	0.185	0.012	0.1	mg/L	是		
					悬浮物	91	17	20	mg/L	是		
					阴离子表面活性剂 (LAS)	9.06	0.91	1	mg/L	是		
					粪大肠菌群数	7000	2300	10000	个/L	是		
					氨氮	172	11.4	15	mg/L	是		
					总氮	196.5	19.4	20	mg/L	是		
					石油类	8.75	2.17	3	mg/L	是		
					动植物油		2.82	3	mg/L	是		
运城市	绛县	绛县生活污水处理厂	2013-5-15	城镇污水处理厂污染物排放标准	温度		11.5					
					PH值		7.61	6-9	无量纲	是		
					生化需氧量		8.35	10	mg/L	是		
					总磷		0.279	0.5	mg/L	是		
					化学需氧量	295	29.5	50	mg/L	是		
					色度		20	30	倍	是		
					总汞		0.00003	0.001	mg/L	是		
					总镉		0.001	0.01	mg/L	是		
					总铬		0.03	0.1	mg/L	是		
					六价铬		0.004	0.05	mg/L	是		

					总铅		0.01	0.1	mg/L	是		
					PH值		8.61	6-9	无量纲	是		
					生化需氧量		4.34	20	mg/L	是		
					总磷		0.84	1	mg/L	是		
					化学需氧量	221	24	60	mg/L	是		
					色度		2	30	倍	是		
					动植物油		0.04	3	mg/L	是		
运城市	平陆县	平陆县供排水公司	2013-5-14	城镇污水处理厂污染物排放标准	温度	21	18.5					
					PH值		7.59	6-9	无量纲	是		
					生化需氧量		8.31	10	mg/L	是		
					总磷		0.41	0.5	mg/L	是		
					化学需氧量	364	42	50	mg/L	是		
					色度		10	30	倍	是		
					总汞		0.00004	0.001	mg/L	是		
					总镉		0.001	0.01	mg/L	是		
					总铬		0.03	0.1	mg/L	是		
					六价铬		0.04	0.05	mg/L	是		
					总砷		0.0046	0.1	mg/L	是		
					总铅		0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.185	0.5	mg/L	是		
					粪大肠菌群数		940	1000	个/L	是		
					氨氮	63.7	3.95	5	mg/L	是		
					总氮		12.2	15	mg/L	是		
石油类		0.22	1	mg/L	是							
动植物油		0.04	1	mg/L	是							
运城市	芮城县	芮城县源清污水处理有限公司	2013-5-27	城镇污水处理厂污染物排放标准	温度		17					
					PH值		7.7	6-9	无量纲	是		
					生化需氧量		8	10	mg/L	是		
					总磷		0.4	0.5	mg/L	是		
					化学需氧量	321	25.3	50	mg/L	是		
					色度		4.8	30	mg/L	是		
					总汞		<0.0005	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		0.05	0.1	mg/L	是		
					六价铬		0.02	0.05	mg/L	是		
					总砷		0.006	0.1	mg/L	是		
					总铅		<0.001	0.1	mg/L	是		
					悬浮物		6	10	mg/L	是		
阴离子表面活性剂 (LAS)		0.06	0.5	mg/L	是							

					粪大肠菌群数		700	1000	个/L	是		
					氨氮	26.1	2.8	5	mg/L	是		
					总氮		12.4	15	mg/L	是		
					石油类		<0.04	1	mg/L	是		
					动植物油		<0.04	1	mg/L	是		
运城市	永济市	永济市污水处理有限责任公司	2013-5-8	城镇污水处理厂污染物排放标准	温度		17.5					
					PH值		7.15	6-9	无量纲	是		
					生化需氧量		13.4	30	mg/L	是		
					总磷		1.08	3	mg/L	是		
					化学需氧量	636	74.4	100	mg/L	是		
					色度		7	40	倍	是		
					总汞		0.0005	0.001	mg/L	是		
					总镉		0.001	0.01	mg/L	是		
					总铬		0.064	0.1	mg/L	是		
					六价铬		0.044	0.05	mg/L	是		
					总砷		0.007	0.1	mg/L	是		
					总铅		0.01	0.1	mg/L	是		
					悬浮物		26	30	mg/L	是		
					阴离子表面活性剂 (LAS)		0.306	2	mg/L	是		
					粪大肠菌群数		790	10000	个/L	是		
					氨氮	42.1	20.9	25	mg/L	是		
					总氮		34.3		mg/L			
					石油类		1.97	5	mg/L	是		
					动植物油		0.88	5	mg/L	是		
					运城市	河津市	河津市污水处理厂	2013-4-8	城镇污水处理厂污染物排放标准	温度		18
PH值		7.78	6-9	无量纲						是		
生化需氧量		9.3	10	mg/L						是		
总磷		0.478	0.5	mg/L						是		
化学需氧量	223	29	50	mg/L						是		
色度		8	30	倍						是		
总汞		0.0007	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.004	0.1	mg/L						是		
六价铬		<0.004	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		7	10	mg/L						是		
阴离子表面活性剂 (LAS)		0.136	0.5	mg/L						是		
粪大肠菌群数		630	1000	个/L						是		
氨氮	25.1	1.22	5	mg/L	是							

					总氮		12.9	15	mg/L	是		
					石油类		0.468	1	mg/L	是		
					动植物油		0.343	1	mg/L	是		
运城市	河津市	中国铝业股份有限公司山西分公司	2013-4-11	城镇污水处理厂污染物排放标准	温度		17.8					
					PH值	8.25	8.02	6-9	无量纲	是		
					生化需氧量	80	8.2	10	mg/L	是		
					总磷	2.07	0.113	0.5	mg/L	是		
					化学需氧量	115	12.2	50	mg/L	是		
					色度	35	19	30	倍	是		
					总汞	0.0004	0.0002	0.001	mg/L	是		
					总镉	0.008	<0.001	0.01	mg/L	是		
					总铬	0.091	<0.004	0.1	mg/L	是		
					六价铬	0.054	<0.004	0.05	mg/L	是		
					总砷	<0.007	<0.007	0.1	mg/L	是		
					总铅	0.096	<0.01	0.1	mg/L	是		
					悬浮物	110	9	10	mg/L	是		
					阴离子表面活性剂 (LAS)	1.31	0.352	0.5	mg/L	是		
					粪大肠菌群数	2400	540	1000	个/L	是		
					氨氮	27.8	0.52	5	mg/L	是		
					总氮	37.2	8.29	15	mg/L	是		
					石油类	0.41	0.275	1	mg/L	是		
					动植物油	0.47	0.347	1	mg/L	是		
					忻州市	忻府区	忻州市污水处理厂	2013-4-27	城镇污水处理厂污染物排放标准	温度		17.5
PH值		8.21	6-9	无量纲						是		
生化需氧量		5.3	20	mg/L						是		
总磷		0.84	1	mg/L						是		
化学需氧量	394	30	60	mg/L						是		
色度		8	30	倍						是		
总汞		<0.00002	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		0.01	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		17	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.21	1	mg/L						是		
粪大肠菌群数		3500	10000	个/L						是		
氨氮	47	6.85	8	mg/L						是		
总氮		14.1	20	mg/L	是							
石油类		0.45	3	mg/L	是							

忻州市	定襄县	定襄县污水处理厂(有限公司)	2013-4-15	城镇污水处理厂污染物排放标准	动植物油	0.55	3	mg/L	是		
					温度	15.2					
					PH值	7.63	6-9	无量纲	是		
					生化需氧量	5.6	20	mg/L	是		
					总磷	0.38	1	mg/L	是		
					化学需氧量	499	31	60	mg/L	是	
					色度	4	30	倍	是		
					总汞	<0.00002	0.001	mg/L	是		
					总镉	<0.001	0.01	mg/L	是		
					总铬	<0.03	0.1	mg/L	是		
					六价铬	0.009	0.05	mg/L	是		
					总砷	<0.007	0.1	mg/L	是		
					总铅	<0.01	0.1	mg/L	是		
					悬浮物	16	20	mg/L	是		
					阴离子表面活性剂(LAS)	0.12	1	mg/L	是		
					粪大肠菌群数		3975	10000	个/L	是	
					氨氮	58.6	1.98	8	mg/L	是	
					总氮		9.18	20	mg/L	是	
					石油类		0.47	3	mg/L	是	
忻州市	五台县	五台县城污水处理基建办公室	2013-4-29	城镇污水处理厂污染物排放标准	动植物油	0.67	3	mg/L	是		
					温度	14.1					
					PH值	7.76	6-9	无量纲	是		
					生化需氧量	4.2	20	mg/L	是		
					总磷	0.31	1	mg/L	是		
					化学需氧量	402	22	60	mg/L	是	
					色度	4	30	倍	是		
					总汞	<0.00002	0.001	mg/L	是		
					总镉	<0.001	0.01	mg/L	是		
					总铬	<0.03	0.1	mg/L	是		
					六价铬	0.006	0.05	mg/L	是		
					总砷	<0.007	0.1	mg/L	是		
					总铅	<0.01	0.1	mg/L	是		
					悬浮物	16	20	mg/L	是		
					阴离子表面活性剂(LAS)	0.11	1	mg/L	是		
					粪大肠菌群数		3500	10000	个/L	是	
					氨氮	34.3	0.367	8	mg/L	是	
					总氮		1.98	20	mg/L	是	
					石油类		0.39	3	mg/L	是	
动植物油		0.53	3	mg/L	是						
					温度	12.5					

忻州市	代 县	代县污水处理厂	2013-4-1	城镇污水处理厂 污染物排放标准	PH值	7.63	6-9	无量纲	是			
					生化需氧量	6.1	20	mg/L	是			
					总磷	0.39	1	mg/L	是			
					化学需氧量	175	32	60	mg/L	是		
					色度	8	30	倍	是			
					总汞	<0.00002	0.001	mg/L	是			
					总镉	<0.001	0.01	mg/L	是			
					总铬	<0.03	0.1	mg/L	是			
					六价铬	0.009	0.05	mg/L	是			
					总砷	<0.007	0.1	mg/L	是			
					总铅	<0.01	0.1	mg/L	是			
					悬浮物	16	20	mg/L	是			
					阴离子表面活性剂 (LAS)	0.11	1	mg/L	是			
					粪大肠菌群数	3500	10000	个/L	是			
					氨氮	22.9	0.235	8	mg/L	是		
					总氮	1.45	20	mg/L	是			
					石油类	0.4	3	mg/L	是			
动植物油	0.44	3	mg/L	是								
忻州市	繁峙县	繁峙县污水处理中心	2013-4-9	城镇污水处理厂 污染物排放标准	温度	12.4						
					PH值	7.64	6-9	无量纲	是			
					生化需氧量	3.7	20	mg/L	是			
					总磷	0.29	1	mg/L	是			
					化学需氧量	282	17	60	mg/L	是		
					色度	6	30	倍	是			
					总汞	<0.00002	0.001	mg/L	是			
					总镉	<0.001	0.01	mg/L	是			
					总铬	<0.03	0.1	mg/L	是			
					六价铬	0.008	0.05	mg/L	是			
					总砷	<0.007	0.1	mg/L	是			
					总铅	<0.01	0.1	mg/L	是			
					悬浮物	15	20	mg/L	是			
					阴离子表面活性剂 (LAS)	0.2	1	mg/L	是			
					粪大肠菌群数	3975	10000	个/L	是			
					氨氮	30.4	4.77	8	mg/L	是		
					总氮	12	20	mg/L	是			
石油类	0.36	3	mg/L	是								
动植物油	0.41	3	mg/L	是								
					温度	10.8						
					PH值	7.6	6-9	无量纲	是			
					生化需氧量	6.5	20	mg/L	是			

忻州市	宁武县	宁武县城污水处理厂	2013-4-16	城镇污水处理厂污染物排放标准	总磷		0.54	1	mg/L	是		
					化学需氧量	339	27	60	mg/L	是		
					色度		6	30	倍	是		
					总汞		<0.00002	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.01	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		16	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.11	1	mg/L	是		
					粪大肠菌群数		3500	10000	个/L	是		
					氨氮	45.3	2.32	15	mg/L	是		
					总氮		11.2	20	mg/L	是		
					石油类		0.56	3	mg/L	是		
					动植物油		0.7	3	mg/L	是		
					忻州市	神池县	神池县污水处理厂	2013-4-13	城镇污水处理厂污染物排放标准	温度		7.3
PH值		8.13	6-9	无量纲						是		
生化需氧量		4.1	20	mg/L						是		
总磷		0.27	1	mg/L						是		
化学需氧量	287	22	60	mg/L						是		
色度		6	30	倍						是		
总汞		<0.00002	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		0.01	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		16	20	mg/L						是		
阴离子表面活性剂 (LAS)		0.13	1	mg/L						是		
粪大肠菌群数		3500	10000	个/L						是		
氨氮	29.9	0.801	15	mg/L						是		
总氮		7.28	20	mg/L						是		
石油类		0.27	3	mg/L	是							
动植物油		0.36	3	mg/L	是							
					温度		10.5					
					总汞		<0.00002	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.007	0.05	mg/L	是		

忻州市	五寨县	五寨县污水处理厂	2013-4-24	城镇污水处理厂 污染物排放标准	总砷	<0.007	0.1	mg/L	是		
					总铅	<0.01	0.1	mg/L	是		
					悬浮物	15	20	mg/L	是		
					阴离子表面活性剂 (LAS)	0.1	1	mg/L	是		
					粪大肠菌群数	3500	10000	个/L	是		
					氨氮	48.2	6.86	15	mg/L	是	
					总氮		14.9	20	mg/L	是	
					石油类		0.49	3	mg/L	是	
					动植物油		0.62	3	mg/L	是	
					PH值		7.85	6-9	无量纲	是	
					生化需氧量		8.2	20	mg/L	是	
					总磷		0.36	1	mg/L	是	
					化学需氧量	428	35	60	mg/L	是	
					色度		4	30	倍	是	
					忻州市	岢岚县	岢岚县城区 污水处理厂	2013-4-3	城镇污水处理厂 污染物排放标准	温度	
PH值		8.11	6-9	无量纲						是	
生化需氧量		7.2	20	mg/L						是	
总磷		0.41	1	mg/L						是	
化学需氧量	405	34	60	mg/L						是	
色度		16	30	倍						是	
总汞		<0.00002	0.001	mg/L						是	
总镉		<0.001	0.01	mg/L						是	
总铬		<0.03	0.1	mg/L						是	
六价铬		0.017	0.05	mg/L						是	
总砷		<0.007	0.1	mg/L						是	
总铅		<0.01	0.1	mg/L						是	
悬浮物		18	20	mg/L						是	
阴离子表面活性剂 (LAS)		0.22	1	mg/L						是	
粪大肠菌群数		5400	10000	个/L						是	
氨氮	51.5	8.64	15	mg/L						是	
总氮		17.8	20	mg/L						是	
石油类		0.41	3	mg/L						是	
动植物油		0.71	3	mg/L	是						
					温度		15.6				
					PH值		7.56	6-9	无量纲	是	
					生化需氧量		8.3	10	mg/L	是	
					总磷		0.45	0.5	mg/L	是	
					化学需氧量	431	35	50	mg/L	是	
					色度		6	30	倍	是	
					总汞	<0.00002	0.001	mg/L	是		

忻州市	河曲县	河曲县城南污水处理厂	2013-4-17	城镇污水处理厂污染物排放标准	总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.01	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.24	0.5	mg/L	是		
					粪大肠菌群数		940	1000	个/L	是		
					氨氮	62.7	0.395	5	mg/L	是		
					总氮		2.57	15	mg/L	是		
					石油类		0.46	1	mg/L	是		
					动植物油		0.56	1	mg/L	是		
					忻州市	保德县	保德县污水处理站	2013-4-17	城镇污水处理厂污染物排放标准	温度		15.2
PH值		7.69	6-9	无量纲						是		
生化需氧量		7.8	10	mg/L						是		
总磷		0.46	0.5	mg/L						是		
化学需氧量	213	30	50	mg/L						是		
色度		8	30	倍						是		
总汞		<0.00002	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		0.012	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		9	10	mg/L						是		
阴离子表面活性剂 (LAS)		0.26	0.5	mg/L						是		
粪大肠菌群数		940	1000	个/L						是		
氨氮	45.3	3.53	5	mg/L						是		
总氮		13.4	15	mg/L						是		
石油类		0.83	1	mg/L						是		
动植物油		0.92	1	mg/L						是		
		偏关县污水		城镇污水处理厂	温度		12.4					
					PH值		7.64	6-9	无量纲	是		
					生化需氧量		8.6	20	mg/L	是		
					总磷		0.61	1	mg/L	是		
					化学需氧量	726	34	60	mg/L	是		
					色度		10	30	倍	是		
					总汞		<0.00002	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		

忻州市	偏关县	偏关县污水处理厂	2013-4-27	城镇污水处理厂污染物排放标准	六价铬		0.012	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		16	20	mg/L	是		
					阴离子表面活性剂 (LAS)		0.18	1	mg/L	是		
					粪大肠菌群数		3975	10000	个/L	是		
					氨氮	39.5	2.62	8	mg/L	是		
					总氮		12	20	mg/L	是		
					石油类		0.76	3	mg/L	是		
					动植物油		0.85	3	mg/L	是		
忻州市	原平市	原平中荷水务有限公司	2013-4-12	城镇污水处理厂污染物排放标准	温度		12					
					PH值		7.34	6-9	无量纲	是		
					生化需氧量		5.9	10	mg/L	是		
					总磷		0.41	0.5	mg/L	是		
					化学需氧量	303	32	50	mg/L	是		
					色度		6	30	倍	是		
					总汞		<0.00002	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.01	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.18	0.5	mg/L	是		
					粪大肠菌群数		940	1000	个/L	是		
					氨氮	35.6	2.3	8	mg/L	是		
					总氮		11.1	15	mg/L	是		
					石油类		0.37	1	mg/L	是		
动植物油		0.54	1	mg/L	是							
临汾市	尧都区	临汾市第二污水处理厂	2013-5-13	城镇污水处理厂污染物排放标准	温度	20.9	19.2					
					PH值	7.8	7.38	6-9	无量纲	是		
					生化需氧量	96	6	10	mg/L	是		
					总磷	2.28	0.49	0.5	mg/L	是		
					化学需氧量	314	30	50	mg/L	是		
					色度	8	4	30	倍	是		
					总汞	0.00031	0.00031	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
总砷	0.001	0.001	0.1	mg/L	是							

					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	80	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	1.72	0.207	0.5	mg/L	是		
					粪大肠菌群数	4600000	84	1000	个/L	是		
					氨氮	46.7	4.96	5	mg/L	是		
					总氮	71.5	13.6	15	mg/L	是		
					石油类	0.1	<0.04	1	mg/L	是		
					动植物油	0.22	0.06	1	mg/L	是		
临汾市	尧都区	临汾市污水处理厂	2013-5-14	城镇污水处理厂污染物排放标准	温度	17.6	19.7					
					PH值	7.56	7.97	6-9	无量纲	是		
					生化需氧量	150	7	30	mg/L	是		
					总磷	3.81	0.58	3	mg/L	是		
					化学需氧量	522	28	100	mg/L	是		
					色度	16	4	40	倍	是		
					总汞	0.00033	0.00029	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	0.005	<0.004	0.05	mg/L	是		
					总砷	<0.0005	<0.0005	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	199	8	30	mg/L	是		
					阴离子表面活性剂 (LAS)	2.704	0.135	2	mg/L	是		
					粪大肠菌群数	20000000	1430	10000	个/L	是		
					氨氮	53.3	8.94	25	mg/L	是		
					总氮	85.4	13.7		mg/L			
					石油类	0.16	<0.04	5	mg/L	是		
					动植物油	0.5	0.05	5	mg/L	是		
临汾市	曲沃县	曲沃县污水处理中心	2013-5-12	城镇污水处理厂污染物排放标准	温度	19.5	22.8					
					PH值	7.5	7.64	6-9	无量纲	是		
					生化需氧量	100	5	10	mg/L	是		
					总磷	3.34	0.48	0.5	mg/L	是		
					化学需氧量	343	23	50	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	107	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	4.39	0.113	0.5	mg/L	是		
					粪大肠菌群数	250000000	49	1000	个/L	是		
					氨氮	39.3	3.2	5	mg/L	是		
					总氮	60.8	9.82	15	mg/L	是		
					色度	32	4	30	倍	是		
					总汞	0.00328	0.00063	0.001	mg/L	是		

					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0018	0.0014	0.1	mg/L	是		
					石油类	1.12	0.15	1	mg/L	是		
					动植物油	3.26	0.19	1	mg/L	是		
临汾市	翼城县	翼城县新源 污水处理有 限公司	2013-5-14	城镇污水处理厂 污染物排放标准	温度	20	21.7					
					总氮	102	14	15	mg/L	是		
					石油类	0.24	<0.04	1	mg/L	是		
					动植物油	0.65	0.05	1	mg/L	是		
					总砷	0.0026	0.0014	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	62	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	3.783	0.181	0.5	mg/L	是		
					粪大肠菌群数	500000000	730	1000	个/L	是		
					氨氮	52.2	2.66	5	mg/L	是		
					化学需氧量	418	31	50	mg/L	是		
					色度	32	8	30	倍	是		
					总汞	0.00036	0.00026	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					PH值	7.83	7.9	6-9	无量纲	是		
					生化需氧量	165	7	10	mg/L	是		
					总磷	3.33	0.48	0.5	mg/L	是		
					临汾市	襄汾县	襄汾县污水 处理厂	2013-5-17	城镇污水处理厂 污染物排放标准	温度	20.3	19.1
PH值	7.53	7.67	6-9	无量纲						是		
生化需氧量	44.5	6	10	mg/L						是		
总磷	3.58	0.48	0.5	mg/L						是		
化学需氧量	145	30	50	mg/L						是		
色度	16	2	30	倍						是		
总汞	0.00005	0.00004	0.001	mg/L						是		
总镉	<0.001	<0.001	0.01	mg/L						是		
总铬	<0.03	<0.03	0.1	mg/L						是		
六价铬	0.005	<0.004	0.05	mg/L						是		
总砷	0.0034	0.0012	0.1	mg/L						是		
总铅	<0.01	<0.01	0.1	mg/L						是		
悬浮物	88	8	10	mg/L						是		
阴离子表面活性剂 (LAS)	1.757	0.154	0.5	mg/L						是		
粪大肠菌群数	160000000	625	1000	个/L	是							

临汾市	浮山县	浮山县污水处理厂	2013-5-12	城镇污水处理厂污染物排放标准	化学需氧量	238	32	60	mg/L	是		
					色度	8	2	30	倍	是		
					温度	16.1	16.4					
					PH值	7.69	7.92	6-9	无量纲	是		
					生化需氧量	80	4	10	mg/L	是		
					总磷	3.85	0.48	0.5	mg/L	是		
					化学需氧量	335	23	50	mg/L	是		
					色度	8	2	30	倍	是		
					总汞	0.00026	0.00005	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0018	0.0013	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	93	9	10	mg/L	是		
					阴离子表面活性剂 (LAS)	2.792	<0.05	0.5	mg/L	是		
					粪大肠菌群数	240000000	300	1000	个/L	是		
					氨氮	48.2	4.24	5	mg/L	是		
					总氮	88.6	10.9	15	mg/L	是		
					石油类	0.34	<0.04	1	mg/L	是		
动植物油	0.69	<0.04	1	mg/L	是							
临汾市	吉 县	吉县污水处理厂	2013-5-15	城镇污水处理厂污染物排放标准	温度	18.2	20.2					
					阴离子表面活性剂 (LAS)	1.813	0.145	0.5	mg/L	是		
					粪大肠菌群数	17000000	825	1000	个/L	是		
					氨氮	17.9	4.32	5	mg/L	是		
					总氮	52.9	13.1	15	mg/L	是		
					石油类	0.09	0.05	1	mg/L	是		
					动植物油	0.16	0.06	1	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0026	0.0019	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	54	7	10	mg/L	是		
					PH值	7.74	7.96	6-9	无量纲	是		
					生化需氧量	28	3	10	mg/L	是		
					总磷	1.81	0.47	0.5	mg/L	是		
					化学需氧量	158	14	50	mg/L	是		
					色度	4	2	30	倍	是		
					总汞	0.00001	<0.00001	0.001	mg/L	是		

临汾市	乡宁县	乡宁县城区污水处理厂	2013-5-13	城镇污水处理厂污染物排放标准	温度	21.6	23.4					
					色度	8	2	30	倍	是		
					总汞	0.00007	0.00006	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.0034	0.0028	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	72	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	2.684	0.227	0.5	mg/L	是		
					粪大肠菌群数	4700000	800	1000	个/L	是		
					氨氮	50.6	3.43	5	mg/L	是		
					总氮	74.1	12.7	15	mg/L	是		
					石油类	0.18	0.08	1	mg/L	是		
					动植物油	0.13	0.05	1	mg/L	是		
					PH值	7.95	7.83	6-9	无量纲	是		
					生化需氧量	65	5	10	mg/L	是		
总磷	2.38	0.48	0.5	mg/L	是							
化学需氧量	212	28	50	mg/L	是							
临汾市	大宁县	大宁县新昕污水处理厂	2013-5-18	城镇污水处理厂污染物排放标准	温度	18.3	19.6					
			2013-5-19		温度	18.3	19.6					
			2013-5-18		PH值	7.78	7.84	6-9	无量纲	是		
					生化需氧量	55	6	10	mg/L	是		
					总磷	2.44	0.48	0.5	mg/L	是		
					化学需氧量	202	29	50	mg/L	是		
					色度	8	2	30	倍	是		
					总汞	0.00012	0.00005	0.001	mg/L	是		
					阴离子表面活性剂 (LAS)	2.324	0.113	0.5	mg/L	是		
					粪大肠菌群数	220000000	775	1000	个/L	是		
					氨氮	27.1	4.33	5	mg/L	是		
					总氮	56	12.6	15	mg/L	是		
					石油类	0.1	0.05	1	mg/L	是		
					动植物油	0.26	0.08	1	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	0.004	<0.004	0.05	mg/L	是		
总砷	0.0028	0.0022	0.1	mg/L	是							
总铅	<0.01	<0.01	0.1	mg/L	是							
悬浮物	59	9	10	mg/L	是							
PH值	7.78	7.84	6-9	无量纲	是							

临汾市	隰县	隰县污水处理厂	2013-5-19	城镇污水处理厂 污染物排放标准	生化需氧量	55	6	10	mg/L	是			
					总磷	2.44	0.48	0.5	mg/L	是			
					化学需氧量	202	29	50	mg/L	是			
					色度	8	2	30	倍	是			
					悬浮物	59	9	10	mg/L	是			
					阴离子表面活性剂 (LAS)	2.324	0.113	0.5	mg/L	是			
					粪大肠菌群数	220000000	775	1000	个/L	是			
					氨氮	27.1	4.33	5	mg/L	是			
					总氮	56	12.6	15	mg/L	是			
					石油类	0.1	0.05	1	mg/L	是			
					总汞	0.00012	0.00005	0.001	mg/L	是			
					总镉	<0.001	<0.001	0.01	mg/L	是			
					总铬	<0.03	<0.03	0.1	mg/L	是			
					六价铬	0.004	<0.004	0.05	mg/L	是			
					总砷	0.0028	0.0022	0.1	mg/L	是			
					总铅	<0.01	<0.01	0.1	mg/L	是			
					动植物油	0.26	0.08	1	mg/L	是			
					2013-5-18	温度	17.2	19.3					
					2013-5-19	温度	17.2	19.3					
					2013-5-18	石油类	0.72	<0.04	1	mg/L	是		
						动植物油	1.63	<0.04	1	mg/L	是		
						总铅	<0.01	<0.01	0.1	mg/L	是		
						悬浮物	68	8	10	mg/L	是		
						阴离子表面活性剂 (LAS)	2.835	<0.05	0.5	mg/L	是		
						粪大肠菌群数	220000000	875	1000	个/L	是		
氨氮	49.4	4.58	5	mg/L		是							
总氮	77.4	13.8	15	mg/L		是							
色度	16	2	30	倍		是							
总汞	0.0001	0.00005	0.001	mg/L		是							
总镉	<0.001	<0.001	0.01	mg/L		是							
总铬	<0.03	<0.03	0.1	mg/L		是							
六价铬	<0.004	<0.004	0.05	mg/L		是							
总砷	0.002	0.0015	0.1	mg/L		是							
PH值	7.61	7.99	6-9	无量纲		是							
生化需氧量	115	4	10	mg/L		是							
总磷	3.43	0.47	0.5	mg/L		是							
化学需氧量	460	12	50	mg/L	是								
PH值	7.61	7.99	6-9	无量纲	是								
生化需氧量	115	4	10	mg/L	是								
总磷	3.43	0.47	0.5	mg/L	是								

			2013-5-19		总氮	77.4	13.8	15	mg/L	是		
					石油类	0.72	<0.04	1	mg/L	是		
					动植物油	1.63	<0.04	1	mg/L	是		
					总砷	0.002	0.0015	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	68	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	2.835	<0.05	0.5	mg/L	是		
					粪大肠菌群数	220000000	875	1000	个/L	是		
					氨氮	49.4	4.58	5	mg/L	是		
					化学需氧量	460	12	50	mg/L	是		
					色度	16	2	30	倍	是		
					总汞	0.0001	0.00005	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					温度	18.4	18.8					
					六价铬	<0.004	<0.004	0.05	mg/L	是		
					总砷	0.002	0.0019	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	98	9	20	mg/L	是		
					阴离子表面活性剂 (LAS)	1.358	0.066	1	mg/L	是		
					粪大肠菌群数	120000000	5600	10000	个/L	是		
					总磷	4.2	0.9	1	mg/L	是		
					化学需氧量	440	24	60	mg/L	是		
					色度	32	4	30	倍	是		
					总汞	0.00048	0.00008	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					氨氮	34.4	7.52	8	mg/L	是		
					总氮	59.1	13.6	20	mg/L	是		
					石油类	0.48	0.06	3	mg/L	是		
					动植物油	1.46	0.09	3	mg/L	是		
					PH值	7.75	7.63	6-9	无量纲	是		
					生化需氧量	140	4	20	mg/L	是		
					温度	16	16.3					
					PH值	7.7	7.88	6-9	无量纲	是		
					生化需氧量	66	4	10	mg/L	是		
					总磷	4.39	0.48	0.5	mg/L	是		
					化学需氧量	311	22	50	mg/L	是		
					色度	16	4	30	倍	是		

临汾市	汾西县	汾西县污水处理厂	2013-5-15	城镇污水处理厂 污染物排放标准	总汞	0.00012	0.00008	0.001	mg/L	是		
					总镉	<0.001	<0.001	0.01	mg/L	是		
					总铬	<0.03	<0.03	0.1	mg/L	是		
					六价铬	0.004	<0.004	0.05	mg/L	是		
					总砷	0.002	0.0018	0.1	mg/L	是		
					总铅	<0.01	<0.01	0.1	mg/L	是		
					悬浮物	84	8	10	mg/L	是		
					阴离子表面活性剂 (LAS)	1.726	0.132	0.5	mg/L	是		
					粪大肠菌群数	220000000	700	1000	个/L	是		
					氨氮	38.2	1.63	5	mg/L	是		
					总氮	52.2	13.2	15	mg/L	是		
					石油类	0.28	<0.04	1	mg/L	是		
					动植物油	0.74	<0.04	1	mg/L	是		
					临汾市	侯马市	侯马市迅速 污水处理有 限公司	2013-5-12	城镇污水处理厂 污染物排放标准	温度	17.5	17.8
PH值	7.45	7.69	6-9	无量纲						是		
生化需氧量	95	6	20	mg/L						是		
氨氮	66.2	7.56	8	mg/L						是		
总氮	90	18.5	20	mg/L						是		
石油类	3.92	0.07	3	mg/L						是		
动植物油	7.2	0.14	3	mg/L						是		
六价铬	0.004	<0.004	0.05	mg/L						是		
总砷	0.0024	0.0013	0.1	mg/L						是		
总铅	<0.01	<0.01	0.1	mg/L						是		
悬浮物	88	8	20	mg/L						是		
阴离子表面活性剂 (LAS)	2.192	0.127	1	mg/L						是		
粪大肠菌群数	61000000	3300	10000	个/L						是		
总磷	5.74	0.98	1	mg/L						是		
化学需氧量	314	31	60	mg/L						是		
色度	8	4	30	倍						是		
总汞	0.0001	0.00002	0.001	mg/L						是		
总镉	<0.001	<0.001	0.01	mg/L						是		
总铬	<0.03	<0.03	0.1	mg/L	是							
					温度	19.9	19.7					
					PH值	7.74	7.56	6-9	无量纲	是		
					生化需氧量	53	15.2	30	mg/L	是		
					总磷	5.81	0.8	3	mg/L	是		
					化学需氧量	158	44	100	mg/L	是		
					色度	24	5	40	倍	是		
					总汞	0.00059	<0.00001	0.001	mg/L	是		
总镉	<0.001	<0.001	0.01	mg/L	是							

临汾市	侯马市	山西侯马晋田热电有限责任公司	2013-5-19	城镇污水处理厂污染物排放标准	总铬	<0.03	<0.03	0.1	mg/L	是							
					六价铬	<0.004	<0.004	0.05	mg/L	是							
					总砷	0.05	0.022	0.1	mg/L	是							
					总铅	<0.01	<0.01	0.1	mg/L	是							
					悬浮物	91	14	30	mg/L	是							
					阴离子表面活性剂 (LAS)	1.2	0.16	2	mg/L	是							
					粪大肠菌群数	13000000000	1600	10000	个/L	是							
					氨氮	37.44	6.552	25	mg/L	是							
					总氮	67.1	17.5		mg/L								
					石油类	0.7	<0.04	5	mg/L	是							
					动植物油	0.53	<0.04	5	mg/L	是							
					临汾市	霍州市	霍州市朝阳污水净化有限责任公司	2013-5-15	城镇污水处理厂污染物排放标准	温度	16.7	17.2					
										总铬	<0.03	<0.03	0.1	mg/L	是		
六价铬	0.005	<0.004	0.05	mg/L						是							
总砷	0.0016	0.0013	0.1	mg/L						是							
总铅	<0.01	<0.01	0.1	mg/L						是							
悬浮物	80	9	10	mg/L						是							
阴离子表面活性剂 (LAS)	2.216	<0.05	0.5	mg/L						是							
生化需氧量	115	6	10	mg/L						是							
总磷	3.03	0.14	0.5	mg/L						是							
化学需氧量	351	37	50	mg/L						是							
色度	16	2	30	倍						是							
总汞	0.00025	0.00014	0.001	mg/L						是							
总镉	<0.001	<0.001	0.01	mg/L						是							
粪大肠菌群数	310000000	82	1000	个/L						是							
氨氮	43.2	2.41	5	mg/L						是							
总氮	49.5	9.01	15	mg/L						是							
石油类	0.71	<0.04	1	mg/L						是							
动植物油	1.23	<0.04	1	mg/L						是							
吕梁市	离石区	吕梁市城区污水处理厂	2013-4-11	城镇污水处理厂污染物排放标准						PH值	7.64	7.92	6-9	无量纲	是		
										温度	11.6	11.1					
					阴离子表面活性剂 (LAS)		0.139	0.5	mg/L	是							
					粪大肠菌群数		560	1000	个/L	是							
					氨氮	27.6	3.65	8	mg/L	是							
					总氮		14.4	15	mg/L	是							
					石油类		0.102	1	mg/L	是							
					动植物油		0.132	1	mg/L	是							
					总镉		<0.001	0.01	mg/L	是							
					总铬		<0.03	0.1	mg/L	是							
六价铬		0.007	0.05	mg/L	是												

		(污水处理)		污染物排放标准	总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					PH值	7.86	7.42	6-9	无量纲	是		
					生化需氧量		8.8	10	mg/L	是		
					总磷		0.471	0.5	mg/L	是		
					化学需氧量	304	43	50	mg/L	是		
					色度		8	30	倍	是		
					总汞		<0.00001	0.001	mg/L	是		
吕梁市	文水县	文水县大运水工业有限公司	2013-4-16	城镇污水处理厂污染物排放标准	温度	17.4	17					
					PH值	7.89	7.51	6-9	无量纲	是		
					生化需氧量		6.3	10	mg/L	是		
					总磷		0.408	0.5	mg/L	是		
					化学需氧量	274	31	50	mg/L	是		
					色度		8	30	倍	是		
					总汞		<0.00001	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.006	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					阴离子表面活性剂 (LAS)		0.098	0.5	mg/L	是		
					粪大肠菌群数		865	1000	个/L	是		
					氨氮	52.4	3.64	5	mg/L	是		
					总氮		13.8	15	mg/L	是		
石油类		0.103	1	mg/L	是							
动植物油		0.121	1	mg/L	是							
吕梁市	交城县	山西省交城县供水公司污水处理厂	2013-4-26	城镇污水处理厂污染物排放标准	温度	14.7	14.7					
					阴离子表面活性剂 (LAS)		0.142	0.5	mg/L	是		
					粪大肠菌群数		630	1000	个/L	是		
					氨氮	56.4	4.11	5	mg/L	是		
					总氮		13.7	15	mg/L	是		
					石油类		0.103	1	mg/L	是		
					动植物油		0.126	1	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.006	0.05	mg/L	是		
总砷		<0.007	0.1	mg/L	是							
总铅		<0.01	0.1	mg/L	是							

					粪大肠菌群数		902	1000	个/L	是		
					氨氮	56.4	4.56	5	mg/L	是		
					总氮		13.3	15	mg/L	是		
					石油类		0.114	1	mg/L	是		
					动植物油		0.138	1	mg/L	是		
吕梁市	柳林县	山西华光发电有限责任公司（柳林县污水处理厂）	2013-4-11	城镇污水处理厂污染物排放标准	温度	15.2	14.4					
					PH值	7.8	7.38	6-9	无量纲	是		
					生化需氧量		4.8	10	mg/L	是		
					总磷		0.381	0.5	mg/L	是		
					化学需氧量	245	24	50	mg/L	是		
					色度		8	30	倍	是		
					总汞		<0.00001	0.001	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.007	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		9	10	mg/L	是		
					阴离子表面活性剂（LAS）		0.12	0.5	mg/L	是		
					粪大肠菌群数		745	1000	个/L	是		
					氨氮	37.5	3.21	5	mg/L	是		
					总氮		13.1	15	mg/L	是		
					石油类		0.082	1	mg/L	是		
					动植物油		0.104	1	mg/L	是		
					吕梁市	中阳县	中阳县玉洁污水处理有限公司	2013-4-26	城镇污水处理厂污染物排放标准	温度	21.1	19.8
PH值	7.87	7.4	6-9	无量纲						是		
生化需氧量		5.9	10	mg/L						是		
总磷		0.4	0.5	mg/L						是		
化学需氧量	258	28.8	50	mg/L						是		
色度		4	30	倍						是		
总汞		<0.00001	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		0.006	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		9	10	mg/L						是		
阴离子表面活性剂（LAS）		0.117	0.5	mg/L						是		
粪大肠菌群数		422	1000	个/L	是							
氨氮	34.1	2.3	5	mg/L	是							

					总氮		10.7	15	mg/L	是		
					石油类		0.102	1	mg/L	是		
					动植物油		0.118	1	mg/L	是		
吕梁市	交口县	交口县清环污水处理有限责任公司	2013-4-11	城镇污水处理厂污染物排放标准	温度	10.2	11.3					
					阴离子表面活性剂 (LAS)		0.128	1	mg/L	是		
					粪大肠菌群数		665	10000	个/L	是		
					氨氮	53.6	3.07	15	mg/L	是		
					总氮		11	20	mg/L	是		
					石油类		0.099	3	mg/L	是		
					动植物油		0.132	3	mg/L	是		
					总镉		<0.001	0.01	mg/L	是		
					总铬		<0.03	0.1	mg/L	是		
					六价铬		0.006	0.05	mg/L	是		
					总砷		<0.007	0.1	mg/L	是		
					总铅		<0.01	0.1	mg/L	是		
					悬浮物		8	20	mg/L	是		
					PH值	7.97	7.54	6-9	无量纲	是		
					生化需氧量		7.4	20	mg/L	是		
					总磷		0.412	1	mg/L	是		
					化学需氧量	436	36	60	mg/L	是		
					色度		8	30	倍	是		
					总汞		<0.00001	0.001	mg/L	是		
					吕梁市	孝义市	孝义市污水处理厂	2013-4-16	城镇污水处理厂污染物排放标准	温度	20.2	20.4
PH值	7.87	7.41	6-9	无量纲						是		
生化需氧量		8.7	10	mg/L						是		
总磷		0.478	0.5	mg/L						是		
化学需氧量	441	40	50	mg/L						是		
色度		8	30	倍						是		
总汞		<0.00001	0.001	mg/L						是		
总镉		<0.001	0.01	mg/L						是		
总铬		<0.03	0.1	mg/L						是		
六价铬		0.007	0.05	mg/L						是		
总砷		<0.007	0.1	mg/L						是		
总铅		<0.01	0.1	mg/L						是		
悬浮物		10	10	mg/L						是		
阴离子表面活性剂 (LAS)		0.128	0.5	mg/L						是		
粪大肠菌群数		805	1000	个/L						是		
氨氮	44.2	4.87	5	mg/L						是		
总氮		14.8	15	mg/L	是							
石油类		0.145	1	mg/L	是							

吕梁市	孝义市	新阳煤矿生活污水处理厂	2013-4-16	城镇污水处理厂污染物排放标准	动植物油		0.167	1	mg/L	是			
					温度	19.1	18						
					PH值	8.13	7.58	6-9	无量纲	是			
					生化需氧量		4.6	10	mg/L	是			
					总磷		0.346	0.5	mg/L	是			
					化学需氧量	173	23	50	mg/L	是			
					色度		4	30	倍	是			
					总汞		<0.00001	0.001	mg/L	是			
					总镉		<0.001	0.01	mg/L	是			
					总铬		<0.03	0.1	mg/L	是			
					六价铬		0.008	0.05	mg/L	是			
					总砷		<0.007	0.1	mg/L	是			
					总铅		<0.01	0.1	mg/L	是			
					悬浮物		9	10	mg/L	是			
					阴离子表面活性剂 (LAS)		0.098	0.5	mg/L	是			
					粪大肠菌群数		630	1000	个/L	是			
					氨氮	28.3	2.71	5	mg/L	是			
					总氮		12.8	15	mg/L	是			
					石油类		0.122	1	mg/L	是			
吕梁市	汾阳市	汾阳市污水处理厂有限公司	2013-4-16	城镇污水处理厂污染物排放标准	动植物油		0.135	1	mg/L	是			
					温度	18	17.9						
					PH值	7.98	7.43	6-9	无量纲	是			
					生化需氧量		8.7	10	mg/L	是			
					总磷		0.442	0.5	mg/L	是			
					化学需氧量	370	40	50	mg/L	是			
					色度		8	30	倍	是			
					总汞		<0.00001	0.001	mg/L	是			
					总镉		<0.001	0.01	mg/L	是			
					总铬		<0.03	0.1	mg/L	是			
					六价铬		0.007	0.05	mg/L	是			
					总砷		<0.007	0.1	mg/L	是			
					总铅		<0.01	0.1	mg/L	是			
					悬浮物		9	10	mg/L	是			
					阴离子表面活性剂 (LAS)		0.184	0.5	mg/L	是			
					粪大肠菌群数		902	1000	个/L	是			
					氨氮	66.7	4.39	5	mg/L	是			
					总氮		14.7	15	mg/L	是			
					石油类		0.11	1	mg/L	是			
动植物油		0.126	1	mg/L	是								